

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAC122		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PERTHEL CUSTOM HOMES						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address P.O. BOX 863						Town of GERMANTOWN									
City MENOMONEE FALLS						State WI		Zip Code 53051				Street Address or Road Name and Number N124 W19813 ISABELL FARMS DR.			
County Washington		Co. Permit #		Notification # 8291445401		Completed 02-24-2021		Subdivision Name ISABELL FARMS				Lot # 4		Block #	
Well Constructor (Business Name) GIBOUR WELL & PUMP SERV INC				Lic. # 4212		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.244 °N -88.1548 °W				Method Code GPS008	
Address 7482 CIRCLE DR LANNON WI 53046				Well Plan Approval #		SE NW		Section 17		Township 9 N		Range 20 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well				of previous unique well # constructed in					
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? Construction Type Drilled							
						Hicap Property ? No									
						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 250		Upper Enlarged Drillhole				Lower Open Bedrock					
						No Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
C		C-CLAY		Surface		60									
L		L-LIMESTONE/DOLOMITE		60		248									
H		H-SHALE		248		250									
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification Manufacturer & Method of Assembly ASTM A53B, SCH40, WHEATLAND, WELDED, BE				From (ft.) Surface		To (ft.) 60							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method															
Kind of Sealing Material GRANULAR BENTONITE				From (ft.) Surface		To (ft.)		# Sacks Cement							
9. Static Water Level															
63 ft. below ground surface															
10. Pump Test															
Pumping level 210 ft. below surface															
Pumping at 40 GP M for 1.5 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
21 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
BG				17		02-25-2021									
Drill Rig Operator				Lic or Reg #		Date Signed									
BG				02-25-2021											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		250

Comment:

Created On: 02-25-2021

Updated On: 03-01-2021

Review Status: APPROVED