Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAC122

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: PERTHEL CUSTOM HOMES	Phone #
Mailing Address: P.O. BOX 863	
City: MENOMONEE FALLS	State: WI — Zip Code: 53051
County: Washington	Co. Permit #: — Notification #: 8291445401 — Completed: 02-24-2021
Well Constructor (Business Name): GIBOUR WELL & PUMP SERV INC	Lic. #: 4212 — Facility ID # (Public Wells):
Address: 7482 CIRCLE DR, LANNON WI 53046	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location
Town of GERMANTOWN
Fire # (if avail.)
Street Address or Road Name and Number: N124 W19813 ISABELL FARMS DR.
Subdivision Name: ISABELL FARMS — Lot #: 4 — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.244 °N -88.1548 °W — Method Code: GPS008
SE NW or Govt Lot #: — Section: 17 — Township: 9 N — Range: 20 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	250

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	C-CLAY	Surface	60
L	L-LIMESTONE/DOLOMITE	60	248
H	H-SHALE	248	250

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B, SCH40, WHEATLAND, WELDED, BE	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
63 ft. below ground surface

10. Pump Test
Pumping level 210 ft. below surface
Pumping at 40 GP M for 1.5 Hrs.
Pumping Method ? Airlift

11. Well Is
21 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
BG	17	02-25-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
BG		02-25-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		250

Comment:

Created On: 02-25-2021 Updated On: 10-15-2026 Review Status: APPROVED