Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAC216

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: AUGUSTYNEK, JAN AND JOLANTA			Phone #
Mailing Address: 9020 S 87TH AVE			
City: HICKORY HILLS	State: IL	Zip Code: 60457	
County: Adams	Co. Permit #:	Notification #: 8142780702	Completed: 11-04-2020

1. Well Location

Town of QUINCY		Fire # (if avail.): 2095
Street Address or Road Name and Number: WIGWAM ST		
Subdivision Name: DELLWOOD SUBDIVISION 2ND ADDITION	Lot #: 23-24	Block #:

Well Constructor (Business Name): QUINNELLS SEPTIC & WELL SERVICE INC	Lic. #: 97	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 43.9525 °N -89.9468 °W	Method Code: GPS008
Address: 1894 DAKOTA AVE FRIENDSHIP WI 53934-9802		Well Plan Approval #:	SW SE or Govt Lot #:	Section: 7	Township: 17 N	Range: 5 E
		Approval Date (mm-dd-yyyy):				
Hicap Permanent Well #:	Common Well #:	Specific Capacity:				

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	46

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	M	S		M-MEDIUM S-SAND	Surface	30
	A	Y		A-COARSE Y-SAND & GRAVEL	30	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	ANSI ASTM 53 SCH 40 T&C	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	CAMPBELL 80 GAUZE	42	46

7. Grout or Other Sealing Material

Method

9. Static Water Level	11. Well Is
21 ft. below ground surface	14 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 21 ft. below surface	Disinfected ? Yes
Pumping at 10 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDQ	5	11-13-2020
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		72	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 09-10-2020 Updated On: 11-16-2020 Review Status: APPROVED