

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAC216		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner AUGUSTYNEK, JAN AND JOLANTA						Phone #													
Mailing Address 9020 S 87TH AVE						1. Well Location						Fire # (if avail.)							
City HICKORY HILLS						State IL		Zip Code 60457				Town of QUINCY		2095					
County Adams						Co. Permit #		Notification # 8142780702				Completed 11-04-2020		Street Address or Road Name and Number WIGWAM ST					
Well Constructor (Business Name) QUINNELLS SEPTIC & WELL SERVICE INC						Lic. # 97		Facility ID # (Public Wells)				Subdivision Name DELLWOOD SUBDIVISION 2ND ADDITION		Lot # 23-24		Block #			
Address 1894 DAKOTA AVE FRIENDSHIP WI 53934-9802						Well Plan Approval #		Approval Date (mm-dd-yyyy)				Latitude / Longitude in Decimal Degree (DD) 43.9525 °N -89.9468 °W		Method Code GPS008					
Hicap Permanent Well #						Common Well #		Specific Capacity				SW SE Section Township Range or Govt Lot # 7 17 N 5 E		2. Well Type New Well					
3. Well serves 1 # of HOME						Hicap Well ? No		Hicap Property ? No				of previous unique well #		constructed in					
Private, potable						Hicap Potable ? No		Heat Exchange ___ # of drillholes				Reason for replaced or reconstructed well ?		Construction Type Jetted					
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method										8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
2		Surface		46		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						M S A Y		M-MEDIUM S-SAND A-COARSE Y-SAND & GRAVEL		Surface 30		30 46	
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)											
2		ANSI ASTM 53 SCH 40 T&C				Surface		42											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
1.25		CAMPBELL 80 GAUZE				42		46											
7. Grout or Other Sealing Material																			
Method																			

9. Static Water Level

21 ft. below ground surface

10. Pump Test

Pumping level 21 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

DDQ

5

11-13-2020

Drill Rig Operator

Lic or Reg #

Date Signed

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		72	Septic or Holding, or POWTS Tank		60

Comment:

Created On: 09-10-2020

Updated On: 11-16-2020

Review Status: APPROVED