Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAE191

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CALVERT CARLA M.	Phone #: (715)923-8281
Mailing Address: N2946 SHORE DRIVE	
City: MARINETTE	State: WI — Zip Code: 54143
County: Marinette	Co. Permit #:
Notification #: 9960202501	Completed: 09-11-2025
Well Constructor (Business Name): KOZIKOWSKI WELL & PUMP INC	Lic. #: 8629
Facility ID # (Public Wells):	
Address: W5515 ELMWOOD RD MENOMINEE MI 49858	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.7	

1. Well Location

City of MARINETTE	Fire # (if avail.): N2946
Street Address or Road Name and Number: N2946 SHORE DRIVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.06554 °N -87.61888 °W	Method Code: GPS008
SW SW or Govt Lot #:	Section: 17 — Township: 30 N — Range: 24 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW WELL DRILLED PFAS AREA

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Borehole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	187
6	187	635

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		U		K-BLACK U-MUD OR MUCK	Surface	2
		S		S-SAND	2	37
		C		C-CLAY	37	40
		S		S-SAND	40	47
		C		C-CLAY	47	55
	S	C	G	S-SOFT/LOOSE C-CLAY G-W/GRAVEL/STONES	55	70
		G	S	G-GRAVEL/STONES S-SANDY	70	90
		C		C-CLAY	90	98
		Z		Z-CLAY & GRAVEL	98	110
		L		L-LIMESTONE/DOLOMITE	110	148
		L	H	L-LIMESTONE/DOLOMITE H-SHALEY	148	247
T		L		T-TAN/BROWN L-LIMESTONE/DOLOMITE	247	292
		L	H	L-LIMESTONE/DOLOMITE H-SHALEY	292	395
		L		L-LIMESTONE/DOLOMITE	395	410
		L	N	L-LIMESTONE/DOLOMITE N-W/SANDSTONE	410	460
R		H		R-RED H-SHALE	460	463
		L	N	L-LIMESTONE/DOLOMITE N-W/SANDSTONE	463	487
		L		L-LIMESTONE/DOLOMITE	487	576
R		H		R-RED H-SHALE	576	578
		L	N	L-LIMESTONE/DOLOMITE N-W/SANDSTONE	578	600
		L		L-LIMESTONE/DOLOMITE	600	618
		N		N-SANDSTONE	618	634

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		L		L-LIMESTONE/DOLOMITE	634	635

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL, 18.97, ASTM A53B , WHEATLAND, WELDED	Surface	187
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

10 ft. below ground surface

10. Pump Test

Pumping level 34 ft. below surface

Pumping at 16 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	187	60 S

12. Notified Owner of need to fill & seal ? Yes

WAITING FOR DIRECTION FROM WDNR

Filled & Sealed Well(s) as needed? No

HOMEOWNER ADVISED OF REQUIREMENTS FALL 2025

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK	56	02-20-2026
Drill Rig Operator	Lic or Reg #	Date Signed
AT	8696	02-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		55

Comment: OLD WELL LOCATED UNDER FRONT ROOM ADDITION AND COVERED WITH SAND. HOMEOWNER ADVISED BY DNR TO ATTEMPT TO LOCATE WELL UNDER ADDITION AND PROPERLY FILL & SEAL PER NR 812.26 REQUIREMENTS. HOMEOWNER TO CONTRACT FOR WORK COMPLETION DUE TO PFAS CONTAMINATION IN OLD WELL.

HOMEOWNER ADVISED OF FILL & SEAL NEEDS SINCE FALL 2025.

Created On: 07-31-2025 Updated On: 10-15-2026 Review Status: APPROVED