

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAE191		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner CALVERT CARLA M.				Phone # (715)923-8281		1. Well Location				Fire # (if avail.)	
Mailing Address N2946 SHORE DRIVE						City of MARINETTE				N2946	
City MARINETTE				State WI		Zip Code 54143					
County Marinette		Co. Permit #		Notification # 9960202501		Completed 09-11-2025		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) KOZIKOWSKI WELL & PUMP INC				Lic. # 8629		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.06554 °N -87.61888 °W		Method Code GPS008	
Address W5515 ELMWOOD RD MENOMINEE MI 49858				Well Plan Approval #		SW SW Section Township Range or Govt Lot # 17 30 N 24 E		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ? NEW WELL DRILLED PFAS AREA			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable Borehole		Hicap Property ? No		Heat Exchange ___ # of drillholes	
Hicap Potable ? No				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology		
10 Surface 187			Yes Rotary - Mud Circulation No			K U K-BLACK U-MUD OR MUCK Surface 2					
6 187 635			No Rotary - Air Yes			S S-SAND 2 37					
			No Rotary - Air & Foam No			C C-CLAY 37 40					
			No Drill-Through Casing Hammer			S S-SAND 40 47					
			No Reverse Rotary			C C-CLAY 47 55					
			No Cable-tool Bit ___ in. dia... No			S C G S-SOFT/LOOSE C-CLAY G-W/GRAVEL/STONES 55 70					
			No Dual Rotary No			G S G-GRAVEL/STONES S-SANDY 70 90					
			No Temp. Outer Casing ___ in. dia			C C-CLAY 90 98					
			No Removed? ___ depth ft. (If NO explain on back side)			Z Z-CLAY & GRAVEL 98 110					
						L L-LIMESTONE/DOLOMITE 110 148					
						L H L-LIMESTONE/DOLOMITE H-SHALEY 148 247					
						T L T-TAN/BROWN L-LIMESTONE/DOLOMITE 247 292					
						L H L-LIMESTONE/DOLOMITE H-SHALEY 292 395					
						L L-LIMESTONE/DOLOMITE 395 410					
						L N L-LIMESTONE/DOLOMITE N-W/SANDSTONE 410 460					
						R H R-RED H-SHALE 460 463					
						L N L-LIMESTONE/DOLOMITE N-W/SANDSTONE 463 487					
						L L-LIMESTONE/DOLOMITE 487 576					
						R H R-RED H-SHALE 576 578					
						L N L-LIMESTONE/DOLOMITE N-W/SANDSTONE 578 600					
						L L-LIMESTONE/DOLOMITE 600 618					
						N N-SANDSTONE 618 634					

				Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
				L	L-LIMESTONE/DOLOMITE	634	635

6. Casing, Liner, Screen <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:10%;">Dia. (in.)</th> <th style="width:40%;">Material, Weight, Specification Manufacturer & Method of Assembly</th> <th style="width:15%;">From (ft.)</th> <th style="width:15%;">To (ft.)</th> </tr> <tr> <td>6</td> <td>BLACK STEEL, 18.97, ASTM A53B , WHEATLAND, WELDED</td> <td>Surface</td> <td>187</td> </tr> <tr> <th>Dia. (in.)</th> <th>Screen type, material & slot size</th> <th>From (ft.)</th> <th>To (ft.)</th> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </table>				Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)	6	BLACK STEEL, 18.97, ASTM A53B , WHEATLAND, WELDED	Surface	187	Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)					9. Static Water Level 10 ft. below ground surface 10. Pump Test Pumping level 34 ft. below surface Pumping at 16 GP M for 1 Hrs. Pumping Method ? Test Pump		11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)																				
6	BLACK STEEL, 18.97, ASTM A53B , WHEATLAND, WELDED	Surface	187																				
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																				

7. Grout or Other Sealing Material Method BRADENHEAD <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:30%;">Kind of Sealing Material</th> <th style="width:10%;">From (ft.)</th> <th style="width:10%;">To (ft.)</th> <th style="width:50%;"># Sacks Cement</th> </tr> <tr> <td>NEAT CEMENT GROUT</td> <td>Surface</td> <td>187</td> <td>60 S</td> </tr> </table>				Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement	NEAT CEMENT GROUT	Surface	187	60 S	12. Notified Owner of need to fill & seal ? Yes WAITING FOR DIRECTION FROM WDNR Filled & Sealed Well(s) as needed? No HOMEOWNER ADVISED OF REQUIREMENTS FALL 2025 <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:60%;">13. Constructor / Supervisory Driller</th> <th style="width:15%;">Lic #</th> <th style="width:25%;">Date Signed</th> </tr> <tr> <td>BK</td> <td>56</td> <td>02-20-2026</td> </tr> <tr> <th>Drill Rig Operator</th> <th>Lic or Reg #</th> <th>Date Signed</th> </tr> <tr> <td>AT</td> <td>8696</td> <td>02-20-2026</td> </tr> </table>				13. Constructor / Supervisory Driller	Lic #	Date Signed	BK	56	02-20-2026	Drill Rig Operator	Lic or Reg #	Date Signed	AT	8696	02-20-2026
Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement																								
NEAT CEMENT GROUT	Surface	187	60 S																								
13. Constructor / Supervisory Driller	Lic #	Date Signed																									
BK	56	02-20-2026																									
Drill Rig Operator	Lic or Reg #	Date Signed																									
AT	8696	02-20-2026																									

4a. Potential Contamination Sources Is the well located in floodplain ? <u>No</u> <table border="1" style="width:100%; border-collapse: collapse;"> <tr> <th style="width:70%;">Type</th> <th style="width:15%;">Qualifier</th> <th style="width:15%;">Distance</th> </tr> <tr> <td>Septic or Holding, or POWTS Tank</td> <td> </td> <td>55</td> </tr> </table> Comment: OLD WELL LOCATED UNDER FRONT ROOM ADDITION AND COVERED WITH SAND. HOMEOWNER ADVISED BY DNR TO ATTEMPT TO LOCATE WELL UNDER ADDITION AND PROPERLY FILL & SEAL PER NR 812.26 REQUIREMENTS. HOMEOWNER TO CONTRACT FOR WORK COMPLETION DUE TO PFAS CONTAMINATION IN OLD WELL. HOMEOWNER ADVISED OF FILL & SEAL NEEDS SINCE FALL 2025.				Type	Qualifier	Distance	Septic or Holding, or POWTS Tank		55
Type	Qualifier	Distance							
Septic or Holding, or POWTS Tank		55							

Created On: 07-31-2025

Updated On: 03-23-2026

Review Status: APPROVED