Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: AAE192

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LACOURT CHUCK	Phone #: (715)923-8281
Mailing Address: W770 CO. B	
City: MARINETTE	State: WI — Zip Code: 54143
County: Marinette	Co. Permit #: WI — Notification #: 9954096701 — Completed: 10-29-2025
Well Constructor (Business Name): KOZIKOWSKI WELL & PUMP INC	Lic. #: 8629 — Facility ID # (Public Wells):
Address: W5515 ELMWOOD RD MENOMINEE MI 49858	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of PESHTIGO			Fire # (if avail.): W770
Street Address or Road Name and Number: W770 CO. B			
Subdivision Name:	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): 45.06855 °N -87.63461 °W			Method Code: SCR002
NE SW or Govt Lot #:	Section: 18	Township: 30 N	Range: 24 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: PFAS CONTAMINATION

Construction Type: Drilled

3. Well serves 1 # of CONCRETE SHOP

Private,potable — Borehole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	162
6	162	526

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, 18.97. ASTM A53B, WHEATLAND, WELDED JOINTS	Surface	162
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method: BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	162	70 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	7
		S		S-SAND	7	51
		Z		Z-CLAY & GRAVEL	51	87
		L		L-LIMESTONE/DOLOMITE	87	141
		L	H	L-LIMESTONE/DOLOMITE H-SHALEY	141	267
		L		L-LIMESTONE/DOLOMITE	267	300
		L	N	L-LIMESTONE/DOLOMITE N-W/SANDSTONE	300	426
R		H		R-RED H-SHALE	426	431
G		L		G-GRAY L-LIMESTONE/DOLOMITE	431	436
R		H		R-RED H-SHALE	436	438
		L	N	L-LIMESTONE/DOLOMITE N-W/SANDSTONE	438	470
		L		L-LIMESTONE/DOLOMITE	470	526

9. Static Water Level	11. Well Is
15 ft. below ground surface	24 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 72 ft. below surface	Disinfected ? Yes
Pumping at 16 GP M for 1 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
BK	56	04-21-2026
Drill Rig Operator	Lic or Reg #	Date Signed
AT	8696	04-21-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		237

Comment:

Created On: 07-31-2025 Updated On: 10-15-2026 Review Status: APPROVED