

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAE193		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PULLIN NICOLE					Phone # (608)213-8167		1. Well Location				Fire # (if avail.)		
Mailing Address N2062 SHORE DRIVE							Town of PESHTIGO				N2062		
City MARINETTE					State WI		Zip Code 54143						
County Marinette		Co. Permit #		Notification # 10034406701		Completed 01-13-2026		Subdivision Name				Lot #	
								Block #					
Well Constructor (Business Name) KOZIKOWSKI WELL & PUMP INC				Lic. # 8629		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.03301 °N -87.62528 °W			
						Well Plan Approval #				Method Code GPS008			
Address W5515 ELMWOOD RD MENOMINEE MI 49858						Approval Date (mm-dd-yyyy)				NW NE Section Township Range or Govt Lot # 31 30 N 24 E			
Hicap Permanent Well #			Common Well #			Specific Capacity 0			2. Well Type Replacement				
									of previous unique well # constructed in				
Reason for replaced or reconstructed well ?									SLOW SAND POINT				
									Construction Type Drilled				
3. Well serves 1 # of HOME												Hicap Well ? No	
Private, potable Drillhole												Hicap Property ? No	
Heat Exchange ___ # of drillholes												Hicap Potable ? No	
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 137			Yes Rotary - Mud Circulation No										
6 137 160			No Rotary - Air Yes										
			No Rotary - Air & Foam No										
			No Drill-Through Casing Hammer										
			No Reverse Rotary										
			No Cable-tool Bit ___ in. dia... No										
			No Dual Rotary No										
			No Temp. Outer Casing ___ in. dia										
			No Removed? ___ depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STEEL, 18.97, A53-B, WHEATLAND , WELDED				Surface		137					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method BRADENHEAD													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
HIGH SOLIDS BENTONITE				Surface		137		8 S					
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S		S-SAND				Surface		30					
X		X-SAND & CLAY				30		57					
C		C-CLAY				57		132					
C Z		C-CLAY Z- W/COBBLES/BOULDERS				132		135					
L		L-LIMESTONE/DOLOMITE				135		160					
9. Static Water Level													
9 ft. below ground surface													
10. Pump Test													
Pumping level 137 ft. below surface													
Pumping at 2 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller				Lic #		Date Signed							
BK				56		01-13-2026							
Drill Rig Operator				Lic or Reg #		Date Signed							
AT				8696		01-13-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		26

Comment:

Created On: 10-28-2025

Updated On: 02-27-2026

Review Status: APPROVED