# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* AAE193

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | |
|---|---|
| Property Owner: PULLIN NICOLE | Phone #: (608)213-8167 |
| Mailing Address: N2062 SHORE DRIVE | |
| City: MARINETTE | State: WI — Zip Code: 54143 |
| County: Marinette | Co. Permit #: |
| Notification #: 10034406701 | Completed: 01-13-2026 |
| Well Constructor (Business Name): KOZIKOWSKI WELL & PUMP INC | Lic. #: 8629 |
| Facility ID # (Public Wells): | |
| Address: W5515 ELMWOOD RD, MENOMINEE MI 49858 | |
| Well Plan Approval #: | |
| Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: |
| Specific Capacity: 0 | |

**1. Well Location**

| | |
|---|---|
| Town of PESHTIGO | Fire # (if avail.): N2062 |
| Street Address or Road Name and Number: N2062 SHORE DRIVE | |
| Subdivision Name: | Lot #: — Block #: |
| Latitude / Longitude in Decimal Degree (DD): 45.03301 °N -87.62528 °W | Method Code: GPS008 |
| NW NE or Govt Lot #: | Section: 31 — Township: 30 N — Range: 24 E |

**2. Well Type** Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SLOW SAND POINT

Construction Type: Drilled

**3. Well serves** 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Dia. (in.) | From (ft.) | To (ft.) |
|---|---|---|
| 8.75 | Surface | 137 |
| 6 | 137 | 160 |

| Upper Enlarged Drillhole | | Lower Open Bedrock |
|---|---|---|
| Yes | Rotary - Mud Circulation ..... | No |
| No | Rotary - Air ..... | Yes |
| No | Rotary - Air & Foam ..... | No |
| No | Drill-Through Casing Hammer | |
| No | Reverse Rotary | |
| No | Cable-tool Bit ____in. dia... | No |
| No | Dual Rotary ..... | No |
| No | Temp. Outer Casing ____in. dia | |
| No | Removed? ____depth ft. (If NO explain on back side) | |

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| | | S | | S-SAND | Surface | 30 |
| | | X | | X-SAND & CLAY | 30 | 57 |
| | | C | | C-CLAY | 57 | 132 |
| | | C | Z | C-CLAY Z-W/COBBLES/BOULDERS | 132 | 135 |
| | | L | | L-LIMESTONE/DOLOMITE | 135 | 160 |

**6. Casing, Liner, Screen**

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 6 | STEEL, 18.97, A53-B, WHEATLAND , WELDED | Surface | 137 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| | | | |

**9. Static Water Level**

9 ft. below ground surface

**10. Pump Test**

Pumping level 137 ft. below surface

Pumping at 2 GP M for 1 Hrs.

Pumping Method ? Airlift

**11. Well Is**

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

**7. Grout or Other Sealing Material**

Method BRADENHEAD

| Kind of Sealing Material | From (ft.) | To (ft.) | # Sacks Cement |
|---|---|---|---|
| HIGH SOLIDS BENTONITE | Surface | 137 | 8 S |

**12.** Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| BK | 56 | 01-13-2026 |
| Drill Rig Operator | Lic or Reg # | Date Signed |
| AT | 8696 | 01-13-2026 |

**4a. Potential Contamination Sources** Is the well located in floodplain ? No

| Type | Qualifier | Distance |
|---|---|---|
| Septic or Holding, or POWTS Tank | | 26 |

Comment:

Created On: 10-28-2025 Updated On: 02-27-2026 Review Status: APPROVED