

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAE194		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner YOUNG LINLEY						Phone # (715)587-6630		1. Well Location				Fire # (if avail.)	
Mailing Address N195 RIVER DRIVE						Town of WAGNER						W2305	
City MENOMINEE						State MI		Zip Code 49858				Street Address or Road Name and Number	
W2305 CO RD. JJ						Subdivision Name				Lot #		Block #	
County Marinette		Co. Permit #		Notification # 10051306401		Completed 11-25-2025		Latitude / Longitude in Decimal Degree (DD)				Method Code	
Well Constructor (Business Name) KOZIKOWSKI WELL & PUMP INC				Lic. # 8629		Facility ID # (Public Wells)				45.32661 °N -87.70787 °W		GPS008	
Address W5515 ELMWOOD RD MENOMINEE MI 49858				Well Plan Approval #		NE SW		Section 13		Township 33 N		Range 22 E	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well			
										of previous unique well # constructed in			
										Reason for replaced or reconstructed well ?			
										Construction Type Drilled			
3. Well serves 1 # of HOME						Hicap Well ? No							
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock										
8.75 Surface 40			Yes Rotary - Mud Circulation No										
6 40 85			No Rotary - Air Yes										
			No Rotary - Air & Foam No										
			No Drill-Through Casing Hammer										
			No Reverse Rotary										
			No Cable-tool Bit ___ in. dia... No										
			No Dual Rotary No										
			No Temp. Outer Casing ___ in. dia										
			No Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)		To (ft.)		
S			S-SAND						Surface		14		
Z			Z-CLAY & GRAVEL						14		20.3		
L			L-LIMESTONE/DOLOMITE						20.3		29		
L N			L-LIMESTONE/DOLOMITE N-W/SANDSTONE						29		43		
L			L-LIMESTONE/DOLOMITE						43		85		
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		BLACK STEEL, 18.97, ASTM A53B, WHEATLAND , WELDED				Surface		40					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method BRADENHEAD													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT GROUT				Surface		40		8 S					
9. Static Water Level													
13 ft. below ground surface													
10. Pump Test													
Pumping level 25 ft. below surface													
Pumping at 60 GP M for 1 Hrs.													
Pumping Method ? Airlift													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller				Lic #		Date Signed							
BK				56		11-25-2025							
Drill Rig Operator				Lic or Reg #		Date Signed							
AT				8696		11-25-2025							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: WILL RETURN TO COLLECT A WATER SAMPLE WHEN THE BUILDING WILL BE HEATED.

Variance ID	Variance or Exception Type	Date	Reason
	Sample Submit Time	01/16/2026	

Created On: 12-10-2025

Updated On: 01-16-2026

Review Status: APPROVED