Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAE497

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: STONER, TYLER & KAREN		Phone #: (715)846-0636
Mailing Address: C/O TIMBER RIDGE BUILDERS / ALEX TAPPE 6909 FEITH AVE.		
City: WESTON	State: WI	Zip Code: 54476

County	Co. Permit #	Notification #	Completed
Marathon		8266038101	01-11-2021

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LANG, ROGER D	205	

Address: LANG WELL DRLG CO INC 1710 GARFIELD AVE, WAUSAU WI 54401-5274

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of MOSINEE

Fire # (if avail.):

Street Address or Road Name and Number: 148670 SMORE LANE MOSINEE, WI

Subdivision Name	Lot #	Block #
FOUR MILE CAMP	14	

Latitude / Longitude in Decimal Degree (DD): 44.8425 °N -89.698 °W

Method Code: GPS008

NW NE or Govt Lot #	Section	Township	Range
	8	27 N	7 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	118

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S		N-FINE S-SAND	Surface	40
		C		C-CLAY	40	90
	D	Q	C	D-DECOMPOSED/WEATHERED Q-GRANITE C-CLAYEY	90	110
R	S	Q		R-RED S-SOFT/LOOSE Q-GRANITE	110	118

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	TMK IPSCO, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PRESSURE TESTED 19.45#/FT., THREADED & COUPLED STEEL	Surface	114
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

11 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 18 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
RDL	205	01-19-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RDL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		30	POWTS dispersal component (soil absorption unit or mound)		100
			Sewer - Building Sanitary		22

Comment:

Created On: 01-12-2021 Updated On: 01-22-2021 Review Status: APPROVED