Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAE498

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: THORPE, KARL	Phone #: (715)551-9890
Mailing Address: C/O WAUSAU HOMES WAUSAU P.O. BOX 8005	
City: WAUSAU	State: WI — Zip Code: 54402
County: Marathon	Co. Permit #:
Notification #: 8269625701	Completed: 01-14-2021
Well Constructor (Business Name): LANG, ROGER D	Lic. #: 205
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: LANG WELL DRLG CO INC 1710 GARFIELD AVE WAUSAU WI 54401-5274	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location
Town of EASTON
Fire # (if avail.):
Street Address or Road Name and Number: 172403 CHURCH RD. ANIWA, WI
Subdivision Name: | Lot #: | Block #:
Latitude / Longitude in Decimal Degree (DD): 45.0152 °N -89.3947 °W
Method Code: GPS008
NW NE or Govt Lot #: | Section: 10 | Township: 29 N | Range: 9 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	9
8	9	40
6	40	300

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 9depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	K	C-CLAY K-W/BROKEN ROCK	Surface	7
		Q		Q-GRANITE	7	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
19 ft. below ground surface

10. Pump Test
Pumping level 210 ft. below surface
Pumping at 7.5 GP M for 26 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	7 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No
NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
RDL	205	01-19-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RDL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO SEPTIC SYSTEM YET

Rehab Type	Rehab Date	Result Text
Hydrofracture	01/14/2021	WELL YIELD BEFORE WAS 45 GPH AFTER IS 7.5 GPM

Created On: 01-18-2021 Updated On: 01-22-2021 Review Status: APPROVED