

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAE498		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner THORPE, KARL						Phone # (715)551-9890		1. Well Location				Fire # (if avail.)									
Mailing Address C/O WAUSAU HOMES WAUSAU P.O. BOX 8005								Town of EASTON													
City WAUSAU						State WI		Zip Code 54402													
County Marathon		Co. Permit #		Notification # 8269625701		Completed 01-14-2021		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) LANG, ROGER D				Lic. # 205		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.0152 °N -89.3947 °W				Method Code GPS008									
Address LANG WELL DRLG CO INC 1710 GARFIELD AVE WAUSAU WI 54401-5274				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 10 29 N 9 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled													
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 0																	
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		9		<u>No</u> Rotary - Mud Circulation				<u>No</u>				C K		C-CLAY K-W/BROKEN ROCK		Surface		7	
8		9		40		<u>Yes</u> Rotary - Air				<u>Yes</u>				Q		Q-GRANITE		7		300	
6		40		300		<u>No</u> Rotary - Air & Foam				<u>No</u>											
						<u>No</u> Drill-Through Casing Hammer															
						<u>No</u> Reverse Rotary															
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>											
						<u>No</u> Dual Rotary				<u>No</u>											
						<u>Yes</u> Temp. Outer Casing 8in. dia															
						<u>Yes</u> Removed? 9depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		19 ft. below ground surface				24 in. above grade							
6		WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE				Surface		40		10. Pump Test Pumping level 210 ft. below surface Pumping at 7.5 GP M for 26 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method BRADENHEAD														12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY											
NEAT CEMENT GROUT				Surface		40		7 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RDL				205		01-19-2021	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														RDL							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: NO SEPTIC SYSTEM YET

Rehab Type	Rehab Date	Result Text
Hydrofracture	01/14/2021	WELL YIELD BEFORE WAS 45 GPH AFTER IS 7.5 GPM

Created On: 01-18-2021

Updated On: 01-22-2021

Review Status: APPROVED