Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAE499

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: FURMANEK, DENNIS	Phone #: (715)848-1219
Mailing Address: 2903 NORTHWESTERN AVE.	
City: WAUSAU	State: WI — Zip Code: 54403
County: Marathon	Co. Permit #: — Notification #: 8270271301 — Completed: 01-19-2021
Well Constructor (Business Name): LANG, ROGER D	Lic. #: 205 — Facility ID # (Public Wells):
Address: LANG WELL DRLG CO INC 1710 GARFIELD AVE WAUSAU WI 54401-5274	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #:	Specific Capacity: 0

1. Well Location
Village of WESTON
Fire # (if avail.):
Street Address or Road Name and Number: 2903 NORTHWESTERN AVE. WAUSAU, WI
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.928 °N -89.5868 °W — Method Code: GPS008
NE NW or Govt Lot #: — Section: 8 — Township: 28 N — Range: 8 E

2. Well Type Replacement
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?
INSUFFICIENT YIELD
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
8	15	40
6	40	300

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 15depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	6
		C	K	C-CLAY K-W/BROKEN ROCK	6	15
G		Q		G-GRAY Q-GRANITE	15	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
20 ft. below ground surface

10. Pump Test
Pumping level 259 ft. below surface
Pumping at 2.6 GP M for 25 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	13 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes
TO BE DONE SOON

13. Constructor / Supervisory Driller	Lic #	Date Signed
RDL	205	01-21-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RDL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		62	POWTS dispersal component (soil absorption unit or mound)		75
			Sewer - Building Sanitary		42

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	01/19/2021	WELL YIELD BEFORE WAS 2 GPH AFTER IS 2.6 GPM

Created On: 01-19-2021 Updated On: 10-15-2026 Review Status: APPROVED