

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAE499		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FURMANEK, DENNIS						Phone # (715)848-1219		1. Well Location				Fire # (if avail.)			
Mailing Address 2903 NORTHWESTERN AVE.								Village of WESTON							
City WAUSAU						State WI		Zip Code 54403							
County Marathon		Co. Permit #		Notification # 8270271301		Completed 01-19-2021		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) LANG, ROGER D						Lic. # 205		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.928 °N -89.5868 °W		Method Code GPS008	
Address LANG WELL DRLG CO INC 1710 GARFIELD AVE WAUSAU WI 54401-5274						Well Plan Approval #		NE NW		Section 8		Township 28 N		Range 8 E	
						Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity		2. Well Type Replacement							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in							
						Hicap Property ? No		Reason for replaced or reconstructed well ?							
						Hicap Potable ? No		INSUFFICIENT YIELD							
								Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
10 Surface 15			No Rotary - Mud Circulation No												
8 15 40			Yes Rotary - Air Yes												
6 40 300			No Rotary - Air & Foam No												
			No Drill-Through Casing Hammer												
			No Reverse Rotary												
			No Cable-tool Bit ___ in. dia... No												
			No Dual Rotary No												
			Yes Temp. Outer Casing 8in. dia												
			Yes Removed? 15depth ft. (If NO explain on back side)												
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
S				S-SAND				Surface		6					
C K				C-CLAY K-W/BROKEN ROCK				6		15					
G Q				G-GRAY Q-GRANITE				15		300					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE				Surface		40							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method BRADENHEAD															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT GROUT				Surface		40		13 S							
9. Static Water Level															
20 ft. below ground surface															
10. Pump Test															
Pumping level 259 ft. below surface															
Pumping at 2.6 GP M for 25 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
TO BE DONE SOON															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
RDL				205 01-21-2021											
Drill Rig Operator				Lic or Reg #				Date Signed							
RDL															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		62	POWTS dispersal component (soil absorption unit or mound)		75
			Sewer - Building Sanitary		42

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	01/19/2021	WELL YIELD BEFORE WAS 2 GPH AFTER IS 2.6 GPM

Created On: 01-19-2021

Updated On: 07-07-2022

Review Status: APPROVED