Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAE500

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LAURILA, DENNIS	Phone #: (715)574-6585
Mailing Address: C/O STEPAN EXTERIORS / TERRY STEPAN 212051 STEPAN DRIVE	
City: MOSINEE	State: WI — Zip Code: 54455
County: Marathon	Co. Permit #:
Notification #: 8275244201	Completed: 02-03-2021
Well Constructor (Business Name): LANG, ROGER D	Lic. #: 205
Facility ID # (Public Wells):	Well Plan Approval #:
Address: LANG WELL DRLG CO INC 1710 GARFIELD AVE WAUSAU WI 54401-5274	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.8	

1. Well Location

Town of MOSINEE

Fire # (if avail.):

Street Address or Road Name and Number: 146166 JULIE LANE MOSINEE, WI

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.7742 °N -89.7312 °W	GPS008

or Govt Lot #	Section	Township	Range
SE SE	36	27 N	6 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	43

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PRESSURE TESTED 19.45#/FT., THREADED & COUPLED STEEL	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL SCREEN (15 SLOT)	40	43

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 25 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
RDL	205	02-03-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RDL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		98	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 02-03-2021 Updated On: 02-24-2021 Review Status: APPROVED