

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAE500		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LAURILA, DENNIS						Phone # (715)574-6585		1. Well Location				Fire # (if avail.)			
Mailing Address C/O STEPAN EXTERIORS / TERRY STEPAN 212051 STEPAN DRIVE						Town of MOSINEE									
City MOSINEE						State WI		Zip Code 54455							
County Marathon		Co. Permit #		Notification # 8275244201		Completed 02-03-2021		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) LANG, ROGER D				Lic. # 205		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7742 °N -89.7312 °W				Method Code GPS008	
Address LANG WELL DRLG CO INC 1710 GARFIELD AVE WAUSAU WI 54401-5274				Well Plan Approval #				SE SE		Section 36		Township 27 N		Range 6 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 2.8				2. Well Type New Well					
Heat Exchange ___ # of drillholes				Hicap Well ? No				Hicap Property ? No				Reason for replaced or reconstructed well ?			
Hicap Potable ? No								Construction Type Drilled							
3. Well serves 1 # of HOME															
Private, potable															
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		43		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
		Y				Y-SAND & GRAVEL		Surface		43					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PRESSURE TESTED 19.45#/FT., THREADED & COUPLED STEEL				Surface		40							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		STAINLESS STEEL SCREEN (15 SLOT)				40		43							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface													
9. Static Water Level															
26 ft. below ground surface															
10. Pump Test															
Pumping level 35 ft. below surface															
Pumping at 25 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?												No			
Filled & Sealed Well(s) as needed?												No			
NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY															
13. Constructor / Supervisory Driller						Lic #		Date Signed							
RDL						205		02-03-2021							
Drill Rig Operator						Lic or Reg #		Date Signed							
RDL															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		98	POWTS dispersal component (soil absorption unit or mound)		95

Comment:

Created On: 02-03-2021

Updated On: 02-24-2021

Review Status: APPROVED