Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAG342

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: SCHMIDT, DAVID AND KRISTI	Phone #
Mailing Address: 1654 87TH AVE	
City: HAMMOND	State: WI — Zip Code: 54015
County: Adams	Co. Permit #: — Notification #: 8184299201 — Completed: 10-28-2020
Well Constructor (Business Name): QUINNELLS SEPTIC & WELL SERVICE INC	Lic. #: 97 — Facility ID # (Public Wells):
Address: 1894 DAKOTA AVE, FRIENDSHIP WI 53934-9802	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of ROME	Fire # (if avail.): 1645
Street Address or Road Name and Number: WOOD RD	
Subdivision Name: BIG BUCK ACRES	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.163 °N -89.885 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 34 — Township: 20 N — Range: 5 E

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Jetted

3. Well serves 1 # of CAMPER
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	67

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S		N-FINE S-SAND	Surface	26
		C		C-CLAY	26	46
	M	S		M-MEDIUM S-SAND	46	56
	A	Y		A-COARSE Y-SAND & GRAVEL	56	67

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	ANSI ASTM 53 SCH 40 T&C	Surface	63
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	CAMPBELL 60 GAUZE	63	67

9. Static Water Level
27 ft. below ground surface

10. Pump Test
Pumping level 27 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DDQ	5	11-09-2020
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO SEPTIC OR DRAINFIELD. LOCATED 18 FOOT FROM CAMPER

Created On: 10-28-2020 Updated On: 11-09-2020 Review Status: APPROVED