

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAG343		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner QUINNELL, BRYAN AND NICOLE						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1870 DAKOTA AVE						Town of STRONGS PRAIRIE						1848					
City FRIENDSHIP						State WI		Zip Code 53934				Street Address or Road Name and Number DAKOTA AVE					
County Adams		Co. Permit #		Notification # 8312817301		Completed 03-15-2021		Subdivision Name				Lot # 1		Block #			
Well Constructor (Business Name) QUINNELLS SEPTIC & WELL SERVICE INC				Lic. # 97		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.982 °N -89.927 °W				Method Code GPS008			
Address 1894 DAKOTA AVE FRIENDSHIP WI 53934-9802				Well Plan Approval #		SW SE		Section 32		Township 18 N		Range 5 E		or Govt Lot #			
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity				2. Well Type New Well					
Hicap Property ? No				Hicap Potable ? No		Reason for replaced or reconstructed well ?				of previous unique well # constructed in							
Heat Exchange ___ # of drillholes				Construction Type Jetted		3. Well serves 1 # of HOME				Private, potable							
4. Potential Contamination Sources - ON REVERSE SIDE				5. Drillhole Dimensions and Construction Method		8. Geology				11. Well Is							
Dia. (in.) 2		From (ft.) Surface		To (ft.) 67		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
						No Rotary - Mud Circulation		No		S S-SAND				Surface		13	
						No Rotary - Air		No		C C-CLAY				13		20	
						No Rotary - Air & Foam		No		M S M-MEDIUM S-SAND				20		52	
						No Drill-Through Casing Hammer				C C-CLAY				52		56	
						No Reverse Rotary				A S A-COARSE S-SAND				56		67	
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is							
Dia. (in.) 2		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) Surface		To (ft.) 64		30 ft. below ground surface				14 in. above grade			
										10. Pump Test				Developed ? Yes			
										Pumping level 30 ft. below surface				Disinfected ? Yes			
										Pumping at 10 GP M for 1 Hrs.				Capped ? No			
										Pumping Method ? Test Pump							
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?				No							
Method						Filled & Sealed Well(s) as needed?				No							
						13. Constructor / Supervisory Driller				Lic #		Date Signed					
						DDQ				5		03-15-2021					
						Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

THERE ARE NO HAZARDS TO REPORT AT TIME OF WELL. THIS IS A NEW BUILD WITH NO SEPTIC SYSTEM OR SURROUNDING BUILDINGS.

Created On: 03-27-2021

Updated On: 07-14-2021

Review Status: APPROVED