

<b>Well Construction Report</b> <b>WISCONSIN UNIQUE WELL NUMBER</b>				<b>AAG777</b>		<b>Drinking Water and Groundwater - DG/5</b> <b>Department of Natural Resources, Box 7921</b> <b>Madison WI 53707</b>				Form 3300-077A											
Property Owner BLUEMOUND RD LLC						Phone #		<b>1. Well Location</b>				Fire # (if avail.)									
Mailing Address PO BOX 126						Village of ELM GROVE						13000									
City WITTENBERG						State WI		Zip Code 54498				Street Address or Road Name and Number W BLUE MOUND RD									
County Waukesha		Co. Permit #		Notification # 8183354704		Completed 12-28-2020		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) SAM'S WELL DRILLING INC				Lic. # 370		Facility ID # (Public Wells) 268188470				Latitude / Longitude in Decimal Degree (DD) 43.0363 °N -88.0748 °W				Method Code GPS008							
Address PO BOX 150 N9935 PLEASANT RD RANDOLPH WI 53956				Well Plan Approval #		NW SE		Section 25		Township 7 N		Range 20 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 0.1		<b>2. Well Type</b> Replacement of previous unique well # constructed in															
Reason for replaced or reconstructed well ? OLD WELL ROTTEN CASING				Construction Type Drilled																	
<b>3. Well serves</b> 1 # of OFFICE COMPLEX Non-community Heat Exchange # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No																	
<b>4. Potential Contamination Sources - ON REVERSE SIDE</b>																					
<b>5. Drillhole Dimensions and Construction Method</b>														<b>8. Geology</b>							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
12		Surface		45		No Rotary - Mud Circulation .....				No		C		C-CLAY		Surface		12			
8		45		318		Yes Rotary - Air .....				Yes		C G		C-CLAY G-W/GRAVEL/STONES		12		24			
						No Rotary - Air & Foam .....				No		L		L-LIMESTONE/DOLOMITE		24		290			
						No Drill-Through Casing Hammer						H		H-SHALE		290		318			
						No Reverse Rotary															
						No Cable-tool Bit ____in. dia...				No											
						No Dual Rotary .....				No											
						Yes Temp. Outer Casing 12in. dia															
						Yes Removed? 24depth ft. (If NO explain on back side)															
<b>6. Casing, Liner, Screen</b>														<b>9. Static Water Level</b>				<b>11. Well Is</b>			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		59 ft. below ground surface				24 in. above grade							
8		STD BLK, PIPE, .322 WALL, P.E., A53B DONGBU				Surface		45		<b>10. Pump Test</b> Pumping level 280 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
<b>7. Grout or Other Sealing Material</b> Method TREMIE PIPE - PUMPED														<b>12. Notified Owner of need to fill &amp; seal ?</b> Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes PUMP INSTALLER TO ABANDON WELL											
NEAT CEMENT GROUT				Surface		45		22 S													
														<b>13. Constructor / Supervisory Driller</b>				Lic #		Date Signed	
														JVG				6026		12-29-2020	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														RA				7375		12-28-2020	

**4a. Potential Contamination Sources**Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary	=	52	Sewer - Building Sanitary	=	35

Comment:

Created On: 12-29-2020

Created by: swdlabs

Updated On: 04-23-2025

Updated by: FRYSMCHQ