Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAH564

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CAMP CORNER CREEK LLC	Phone #
Mailing Address: 558 SOUTH STATE ROAD	
City: FALL CREEK	State: WI — Zip Code: 54742
County: Clark	Co. Permit #: — Notification #: 8306130502 — Completed: 03-12-2021
Well Constructor (Business Name): MIDWEST HYDROFRACKING LLC	Lic. #: 6799 — Facility ID # (Public Wells):
Address: 31569 150TH AV CORNELL WI 54732-6100	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of PINE VALLEY	Fire # (if avail.): W6796
Street Address or Road Name and Number: POERTNER ROAD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.5099 °N -90.6518 °W	Method Code: GPS008
SE SW or Govt Lot #:	Section: 32 — Township: 24 N — Range: 2 W

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of CAMPGROUND

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	205

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	C		T-TAN/BROWN V-NON-CAVING C-CLAY	Surface	48
K	H	Q		K-BLACK H-HARD/FIRM Q-GRANITE	48	205

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 18.97#FT A53B ASTM WHEATLAND	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 121 ft. below surface

Pumping at 5 GP M for 3 Hrs.

Pumping Method ? Test Pump

11. Well Is

29 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MSP	8236	03-12-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MSP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		103	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 03-15-2021 Updated On: 03-29-2021 Review Status: APPROVED