

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAH564		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner CAMP CORNER CREEK LLC						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 558 SOUTH STATE ROAD						Town of PINE VALLEY				W6796					
City FALL CREEK						State WI		Zip Code 54742				Street Address or Road Name and Number POERTNER ROAD			
County Clark		Co. Permit #		Notification # 8306130502		Completed 03-12-2021		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) MIDWEST HYDROFRACKING LLC				Lic. # 6799		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5099 °N -90.6518 °W			Method Code GPS008		
Address 31569 150TH AV CORNELL WI 54732-6100				Well Plan Approval #				SE SW		Section 32		Township 24 N		Range 2 W	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #			Common Well #			Specific Capacity 0				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
3. Well serves 1 # of CAMPGROUND						Hicap Well ? No									
Private, potable						Hicap Property ? No									
Heat Exchange ___ # of drillholes						Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		205		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>Yes</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T V C				T-TAN/BROWN V-NON-CAVING C-CLAY				Surface		48					
K H Q				K-BLACK H-HARD/FIRM Q-GRANITE				48		205					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW STEEL 18.97#FT A53B ASTM WHEATLAND				Surface		48							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface				2 S							
9. Static Water Level															
6 ft. below ground surface															
10. Pump Test															
Pumping level 121 ft. below surface															
Pumping at 5 GP M for 3 Hrs.															
Pumping Method ? Test Pump															
11. Well Is															
29 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? Yes															
Filled & Sealed Well(s) as needed? Yes															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
MSP				8236				03-12-2021							
Drill Rig Operator				Lic or Reg #				Date Signed							
MSP															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		103	Septic or Holding, or POWTS Tank		95

Comment:

Created On: 03-15-2021

Updated On: 03-29-2021

Review Status: APPROVED