

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAH566		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner SCHMIDT, DAVID					Phone #		1. Well Location Fire # (if avail.) N5496					
Mailing Address N5496 THORNAPPLE ROAD												
City LADYSMITH			State WI		Zip Code 54848		Town of THORNAPPLE Street Address or Road Name and Number THORNAPPLE ROAD					
County Rusk		Co. Permit #		Notification # 8318686001		Completed 03-17-2021		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) MIDWEST HYDROFRACKING LLC				Lic. # 6799		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.4862 °N -91.2357 °W			Method Code GPS008	
Address 31569 150TH AV CORNELL WI 54732-6100				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 27 35 N 7 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? LOW YEILD Construction Type Drilled				
				Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #		Specific Capacity 0							
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
6		Surface		78		No Rotary - Mud Circulation Yes Rotary - Air No Rotary - Air & Foam No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				T Q S T-TAN/BROWN Q-CAVING S-SAND T Q Y T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL Q G Q-CAVING G-GRAVEL/STONES		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 51 ft. below ground surface		
6		NEW STEEL 18.97#FT A53B ASTM WHEATLAND P.E WELDED				Surface		78		10. Pump Test Pumping level 60 ft. below surface Pumping at 15 GP M for 14 Hrs. Pumping Method ? Test Pump		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is 28 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes		
7. Grout or Other Sealing Material												
Method MOUNDED												
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? FINISHED		
GRANULAR BENTONITE				Surface				1 S		Yes		
13. Constructor / Supervisory Driller												
MSP				Lic # 8236		Date Signed 03-17-2021						
Drill Rig Operator				Lic or Reg #		Date Signed						
MSP												

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		83	Septic or Holding, or POWTS Tank		75

Comment:

Created On: 03-19-2021

Updated On: 04-14-2021

Review Status: APPROVED