

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAH799		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner PASCH, TYLER						Phone # (715)307-2512		1. Well Location				Fire # (if avail.)	
Mailing Address W7405 570TH AVENUE						Town of TRIMBELLE						W7405	
City ELLSWORTH						State WI		Zip Code 54011				Street Address or Road Name and Number 570TH AVENUE	
County Pierce		Co. Permit #		Notification # 9659449901		Completed 10-21-2024		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) KIMMES-BAUER WELL DRILLING INC				Lic. # 59		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7541 °N -92.5023 °W			
Address 22100 LILLEHEI AVE HASTINGS MN 55033				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 12 26 N 18 W		2. Well Type Replacement				of previous unique well # constructed in	
				Approval Date (mm-dd-yyyy)		Reason for replaced or reconstructed well ? HIGH METALS				Construction Type Drilled			
Hicap Permanent Well #				Common Well #		Specific Capacity		Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No	
3. Well serves 1 # of HOME Private,potable												Construction Type Drilled	
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				8. Geology		
15 Surface 58			<u>Yes</u> Rotary - Mud Circulation <u>No</u>				T Q Z T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL				From (ft.) To (ft.) Surface 53		
10 58 567			<u>No</u> Rotary - Air <u>No</u>				Y V L Y-YELLOW V-NON-CAVING L-LIMESTONE/DOLOMITE				53 63		
6 567 600			<u>No</u> Rotary - Air & Foam <u>Yes</u>				U V H U-BLUE V-NON-CAVING H-SHALE				63 131		
			<u>No</u> Drill-Through Casing Hammer				G V L G-GRAY V-NON-CAVING L-LIMESTONE/DOLOMITE				131 150		
			<u>No</u> Reverse Rotary				E V H E-GREEN V-NON-CAVING H-SHALE				150 157		
			<u>No</u> Cable-tool Bit ___ in. dia... <u>No</u>				I V N I-WHITE V-NON-CAVING N-SANDSTONE				157 282		
			<u>No</u> Dual Rotary <u>No</u>				Y V L Y-YELLOW V-NON-CAVING L-LIMESTONE/DOLOMITE				282 553		
			<u>Yes</u> Temp. Outer Casing 10in. dia				G V N G-GRAY V-NON-CAVING N-SANDSTONE				553 600		
			<u>Yes</u> Removed? 58depth ft. (If NO explain on back side)										
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		HUSTEEL A53B STEEL WELDED				Surface		567					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT GROUT				Surface		567		10 Y					

9. Static Water Level

265 ft. below ground surface

10. Pump Test

Pumping level 265 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

Yes

WELL SEALED ON 11/1/24

13. Constructor / Supervisory Driller

Lic #

Date Signed

AB

7474

11-07-2024

Drill Rig Operator

Lic or Reg #

Date Signed

CI

8312

11-07-2024

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type

Qualifier

Distance

Petroleum Tank - Surface

20

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Other Variance	10/21/2024	SIGNIFICANT LOSS OF GROUT

Created On: 11-07-2024

Updated On: 11-25-2024

Review Status: APPROVED