Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAH799

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PASCH, TYLER	Phone #: (715)307-2512
Mailing Address: W7405 570TH AVENUE	
City: ELLSWORTH	State: WI — Zip Code: 54011
County: Pierce	Co. Permit #:
Notification #: 9659449901	Completed: 10-21-2024
Well Constructor (Business Name): KIMMES-BAUER WELL DRILLING INC	Lic. #: 59
Facility ID # (Public Wells):	
Address: 22100 LILLEHEI AVE HASTINGS MN 55033	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity:	

1. Well Location

Town of TRIMBELLE	Fire # (if avail.): W7405
Street Address or Road Name and Number: 570TH AVENUE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.7541 °N -92.5023 °W	Method Code: SCR002
SW NE or Govt Lot #:	Section: 12 — Township: 26 N — Range: 18 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: HIGH METALS

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
15	Surface	58
10	58	567
6	567	600

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 58depth ft. (If NO explain on back side)	

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	HUSTEEL A53B STEEL WELDED	Surface	567
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	567	10 Y

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	Z		T-TAN/BROWN Q-CAVING Z-CLAY & GRAVEL	Surface	53
Y	V	L		Y-YELLOW V-NON-CAVING L-LIMESTONE/DOLOMITE	53	63
U	V	H		U-BLUE V-NON-CAVING H-SHALE	63	131
G	V	L		G-GRAY V-NON-CAVING L-LIMESTONE/DOLOMITE	131	150
E	V	H		E-GREEN V-NON-CAVING H-SHALE	150	157
I	V	N		I-WHITE V-NON-CAVING N-SANDSTONE	157	282
Y	V	L		Y-YELLOW V-NON-CAVING L-LIMESTONE/DOLOMITE	282	553
G	V	N		G-GRAY V-NON-CAVING N-SANDSTONE	553	600

9. Static Water Level	11. Well Is
265 ft. below ground surface	16 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 265 ft. below surface	Disinfected ? Yes
Pumping at 10 GP M for 2 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

WELL SEALED ON 11/1/24

13. Constructor / Supervisory Driller	Lic #	Date Signed
AB	7474	11-07-2024
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
CI	8312	11-07-2024

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Petroleum Tank - Surface		20

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Other Variance	10/21/2024	SIGNIFICANT LOSS OF GROUT

Created On: 11-07-2024 Updated On: 11-25-2024 Review Status: APPROVED