Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAH857

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KIETRYS, CHRIS	Phone #: (715)383-5204
Mailing Address: 3368; VERBUNKER AVE	
City: PORT EDWARDS	State: WI — Zip Code: 54469
County: Portage	Co. Permit #:
Notification #: 8402274901	Completed: 05-11-2021
Well Constructor (Business Name): HAUPT WELL & PUMP CO INC	Lic. #: 529
Facility ID # (Public Wells):	
Address: 5508 MAIN ST AUBURNDALE WI 54412	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 1.9	

1. Well Location

Town of EAU PLEINE	Fire # (if avail.): 4030
Street Address or Road Name and Number: COUNTY ROAD E	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.6533 °N -89.6784 °W	Method Code: GPS008

NW	NE	Section	Township	Range
or Govt Lot #		16	25 N	7 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	29

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	29

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A53 IPSCO WELD	Surface	26
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS ALLOY WIRE WOUND 12 SLOT K PACKER AND PLUG BOTTOM	26	29

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

4.5 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AH	6577	05-11-2021
Drill Rig Operator	Lic or Reg #	Date Signed
AH	6577	05-11-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 05-11-2021 Updated On: 10-15-2026 Review Status: APPROVED