Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAH858

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZARLING, GREGORY	Phone #: (414)719-0851
Mailing Address: 2425 SOUTH 5TH STREET	
City: MILWAUKEE	State: WI — Zip Code: 53207

County	Co. Permit #	Notification #	Completed
Clark		8406597801	05-14-2021

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HAUPT WELL & PUMP CO INC	529	

Address: 5508 MAIN ST
AUBURNDALE WI 54412

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0

3. Well serves 1 # of CABIN

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of LEVIS

Fire # (if avail.): N1696

Street Address or Road Name and Number: CLARK AV

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 44.4767 °N -90.656 °W

Method Code: GPS008

NW	NW	Section	Township	Range
or Govt Lot #		17	23 N	2 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	40
6	40	240

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 7depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	C-CLAY G-W/GRAVEL/STONES	Surface	7
		Q		Q-GRANITE	7	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A53 IPSCO WELD	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	5 S

9. Static Water Level

2.3 ft. below ground surface

10. Pump Test

Pumping level 240 ft. below surface

Pumping at 7.5 GP H for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

28 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
GH	7	05-14-2021
Drill Rig Operator	Lic or Reg #	Date Signed
GH	7	05-14-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: OWNER CHOOSE NOT TO FRACK BECAUSE HE THINKS THE CURRENT YIELD IS SUFFICIENT FOR THE INTENDED USE

Created On: 05-13-2021 Updated On: 10-15-2026 Review Status: APPROVED