

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAH858		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner ZARLING, GREGORY				Phone # (414)719-0851		1. Well Location				Fire # (if avail.)		
Mailing Address 2425 SOUTH 5TH STREET						Town of LEVIS				N1696		
City MILWAUKEE				State WI		Zip Code 53207				Street Address or Road Name and Number		
County Clark				Co. Permit #		Notification # 8406597801				Completed 05-14-2021		
Well Constructor (Business Name)				Lic. # 529		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)		
HAUPT WELL & PUMP CO INC						44.4767 °N -90.656 °W				Method Code GPS008		
Address 5508 MAIN ST AUBURNDALE WI 54412				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 17 23 N 2 W				2. Well Type New Well		
Hicap Permanent Well #				Common Well #		Specific Capacity 1.9				Reason for replaced or reconstructed well ?		
3. Well serves 1 # of CABIN				Hicap Well ? No		Private, potable Drillhole				Hicap Property ? No		
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole						Lower Open Bedrock			
8	Surface	40	No Rotary - Mud Circulation						No			
6	40	240	Yes Rotary - Air						Yes			
			No Rotary - Air & Foam						No			
			No Drill-Through Casing Hammer									
			No Reverse Rotary									
			No Cable-tool Bit ___ in. dia...						No			
			No Dual Rotary						No			
			Yes Temp. Outer Casing 8in. dia									
			Yes Removed? 7depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen												
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)						
6	STEEL 18.97 A53 IPSCO WELD				Surface	40						
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)						
7. Grout or Other Sealing Material												
Method TREMIE PIPE - PUMPED												
Kind of Sealing Material				From (ft.)	To (ft.)	# Sacks Cement						
NEAT CEMENT GROUT				Surface	40	5 S						
8. Geology												
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)	To (ft.)					
	C	G	C-CLAY G-W/GRAVEL/STONES				Surface	7				
	Q		Q-GRANITE				7	240				
9. Static Water Level												
2.3 ft. below ground surface												
10. Pump Test												
Pumping level 240 ft. below surface												
Pumping at 7.5 GP H for 2 Hrs.												
Pumping Method ? Airlift												
11. Well Is												
28 in. above grade												
Developed ? Yes												
Disinfected ? Yes												
Capped ? Yes												
12. Notified Owner of need to fill & seal ? No												
Filled & Sealed Well(s) as needed? No												
13. Constructor / Supervisory Driller												
GH				Lic # 7		Date Signed 05-14-2021						
Drill Rig Operator				Lic or Reg #		Date Signed						
GH				7		05-14-2021						

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: OWNER CHOOSE NOT TO FRACK BECAUSE HE THINKS THE CURRENT YIELD IS SUFFICIENT FOR THE INTENDED USE

Created On: 05-13-2021

Updated On: 08-06-2021

Review Status: APPROVED