

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAH859		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner URLAUB, JEFF						Phone # (715)828-8592					
Mailing Address 1800 MENNOMONIE STREET											
City EAU CLAIRE				State WI		Zip Code 54703					
County Clark		Co. Permit #		Notification # 8414476901		Completed 05-26-2021					
Well Constructor (Business Name) HAUPT WELL & PUMP CO INC						Lic. # 529		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)	
Address 5508 MAIN ST AUBURNDALE WI 54412						Well Plan Approval #		Approval Date (mm-dd-yyyy)		44.4952 °N -90.6455 °W	
										Method Code GPS008	
Hicap Permanent Well #		Common Well #		Specific Capacity 0		SW SE		Section 5		Township 23 N	
3. Well serves 1 # of HOME		Private, potable		Drillhole		Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No	
Heat Exchange ___ # of drillholes										Construction Type Drilled	
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole				Lower Open Bedrock				
8	Surface	40	No Rotary - Mud Circulation				No				
6	40	240	Yes Rotary - Air				Yes				
			No Rotary - Air & Foam				No				
			No Drill-Through Casing Hammer								
			No Reverse Rotary								
			No Cable-tool Bit ___ in. dia...				No				
			No Dual Rotary				No				
			Yes Temp. Outer Casing 8in. dia								
			Yes Removed? 18depth ft. (If NO explain on back side)								
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
	X	X-SAND & CLAY				Surface		6			
	Y	Y-SAND & GRAVEL				6		19			
D	Q	D-DECOMPOSED/WEATHERED Q-GRANITE				19		21			
R	Q	R-RED Q-GRANITE				21		26			
H	Q	H-HARD/FIRM Q-GRANITE				26		240			
6. Casing, Liner, Screen											
Dia. (in.)	Material, Weight, Specification				From (ft.)		To (ft.)				
6	STEEL 18.97 A53 IPSCO WELD				Surface		40				
Dia. (in.)	Screen type, material & slot size				From (ft.)		To (ft.)				
7. Grout or Other Sealing Material											
Method TREMIE PIPE - PUMPED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
NEAT CEMENT GROUT		Surface		40		12 S					
9. Static Water Level											
24 ft. below ground surface											
10. Pump Test											
Pumping level 240 ft. below surface											
Pumping at 4 GP M for 1.5 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
28 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
GH		7 05-26-2021									
Drill Rig Operator		Lic or Reg # Date Signed									
GH		7 05-26-2021									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	=	190	POWTS holding component (also known as holding tank)	=	45

Comment:

Created On: 05-20-2021

Updated On: 09-14-2021

Review Status: APPROVED