Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAH860

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KAYHART, SAM	Phone #: (715)897-3322
Mailing Address: 10641 COUNTY RD B	
City: MARSHFIELD	State: WI — Zip Code: 54449
County: Wood	Co. Permit #:
Notification #: 8551857101	Completed: 10-07-2021
Well Constructor (Business Name): HAUPT WELL & PUMP CO INC	Lic. #: 529
Facility ID # (Public Wells):	
Address: 5508 MAIN ST AUBURNDALE WI 54412	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of ROCK	Fire # (if avail.): 10041
Street Address or Road Name and Number: EISENHOWER DRIVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.569 °N -90.2156 °W	Method Code: GPS008
NW NW or Govt Lot #:	Section: 13 — Township: 24 N — Range: 2 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable — Drillhole

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	50.5
6	50.5	182

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
No	Removed? 20depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S	X	N	S-SOFT/LOOSE X-SAND & CLAY N-W/SANDSTONE	Surface	20
		C	N	C-CLAY N-W/SANDSTONE	20	35
		H	S	H-SHALE S-SANDY	35	49
	H	Q		H-HARD/FIRM Q-GRANITE	49	182

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL 18.97 A53 IPSCO WELDED	Surface	50.5
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	50.5	7 S

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 182 ft. below surface

Pumping at 7 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

36 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
AH	6577	10-07-2021
Drill Rig Operator	Lic or Reg #	Date Signed
AH	6577	10-07-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	200	Septic or Holding, or POWTS Tank	=	40

Comment:

Created On: 10-07-2021 Updated On: 02-04-2022 Review Status: APPROVED