

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAH860		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner KAYHART, SAM					Phone # (715)897-3322		1. Well Location				Fire # (if avail.)								
Mailing Address 10641 COUNTY RD B							Town of ROCK				10041								
City MARSHFIELD					State WI		Zip Code 54449				Street Address or Road Name and Number EISENHOWER DRIVE								
County Wood		Co. Permit #		Notification # 8551857101		Completed 10-07-2021		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) HAUPT WELL & PUMP CO INC				Lic. # 529		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.569 °N -90.2156 °W				Method Code GPS008							
Address 5508 MAIN ST AUBURNDAL WI 54412				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 13 24 N 2 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0															
3. Well serves 1 # of HOME Private, potable Drillhole Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
8		Surface		50.5		<u>No</u> Rotary - Mud Circulation		<u>No</u>		S X N		S-SOFT/LOOSE X-SAND & CLAY N-W/SANDSTONE		Surface		20			
6		50.5		182		<u>Yes</u> Rotary - Air		<u>Yes</u>		C N		C-CLAY N-W/SANDSTONE		20		35			
						<u>No</u> Rotary - Air & Foam		<u>No</u>		H S		H-SHALE S-SANDY		35		49			
						<u>No</u> Drill-Through Casing Hammer				H Q		H-HARD/FIRM Q-GRANITE		49		182			
						<u>No</u> Reverse Rotary													
						<u>No</u> Cable-tool Bit ___ in. dia...		<u>No</u>											
						<u>No</u> Dual Rotary		<u>No</u>											
						<u>Yes</u> Temp. Outer Casing 8in. dia													
						<u>No</u> Removed? 20depth ft. (If NO explain on back side)													
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				36 in. above grade					
6		STEEL 18.97 A53 IPSCO WELDED				Surface		50.5		10. Pump Test Pumping level 182 ft. below surface Pumping at 7 GP M for 1 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
NEAT CEMENT GROUT				Surface		50.5		7 S											
												13. Constructor / Supervisory Driller Lic # Date Signed AH 6577 10-07-2021 Drill Rig Operator Lic or Reg # Date Signed AH 6577 10-07-2021							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	200	Septic or Holding, or POWTS Tank	=	40

Comment:

Created On: 10-07-2021

Updated On: 02-04-2022

Review Status: APPROVED