Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAK026

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DON BISHOP	Phone #: (608)931-2980
Mailing Address: 6327 S. KETTLE RD	
City: BELOIT	State: WI — Zip Code: 53511
County: Rock	Co. Permit #:
Notification #: 9975038101	Completed: 09-10-2025
Well Constructor (Business Name): MARTIN, CHARLES WADE	Lic. #: 6623
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 1192 PRAIRIE LN MACHESNEY PARK IL 61115	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 2.2	

1. Well Location

Town of NEWARK	Fire # (if avail.): 7817
Street Address or Road Name and Number: W. STATE RD. 81	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 42.52077 °N -89.15282 °W	Method Code: SCR002
SE NE or Govt Lot #:	Section: 26 — Township: 1 N — Range: 11 E

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: SHARED WELL ON NEIGHBORS PROPERTY. NO ONE LIVING IN HOUSE WITH WELL THEY ARE GOING TO TURN THE HEAT OFF THIS WINTER

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	73
6	73	150

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K	E	T	C	K-BLACK E-CLEAN T-TILL C-CLAYEY	Surface	2
Y	S	L	K	Y-YELLOW S-SOFT/LOOSE L-LIMESTONE/DOLOMITE K-W/BROKEN ROCK	2	35
T	V	C	H	T-TAN/BROWN V-NON-CAVING C-CLAY H-SHALEY	35	45
U	H	H	H	U-BLUE H-HARD/FIRM H-SHALE H-SHALEY	45	60
I	S	N	S	I-WHITE S-SOFT/LOOSE N-SANDSTONE S-SANDY	60	65
T	H	N	S	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE S-SANDY	65	150

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL ASTM A53B WHEATLAND THREAD AND COUPLED	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GROUT DISPLACEMENT (PLUG)

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	73	24 S

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 22 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

N/A

Filled & Sealed Well(s) as needed? No

N/A

13. Constructor / Supervisory Driller	Lic #	Date Signed
CWM	6623	09-27-2025
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		80

Comment:

Created On: 09-27-2025 Updated On: 10-15-2026 Review Status: APPROVED