

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAK525		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner LONG,MARY				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 5051 SACRED FEATHER DRIVE				Town of NASEWAUPEE		2389				Street Address or Road Name and Number	
City COLORADO SPRINGS				State CO		Zip Code 80916				COUNTY S	
County		Co. Permit #		Notification #		Completed		Subdivision Name		Lot #	
Door		8499015801		10-11-2021		Block #					
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)		Method Code	
EUCLIDE, MARK E				5905		Well Plan Approval #		44.7867 °N -87.3985 °W		GPS008	
Address EUCLIDE WELL DRILLING INC 2496 STONE RD STURGEON BAY WI 54235				Approval Date (mm-dd-yyyy)		SE NE Section Township Range or Govt Lot # 25 27 N 25 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?			
0.2				3. Well serves 1 # of HOME		Hicap Well ? No		Construction Type Drilled			
Private,potable				Hicap Property ? No		Hicap Potable ? No					
Heat Exchange ___ # of drillholes											
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
10		Surface		38		Yes Rotary - Mud Circulation		No		Geology Codes	
8		38		170		Yes Rotary - Air		No		Type, Caving/Noncaving, Color, Hardness, etc...	
6		170		262		No Rotary - Air & Foam		No		From (ft.) To (ft.)	
						No Drill-Through Casing Hammer		No		T Z T-TAN/BROWN Z-CLAY & GRAVEL	
						No Reverse Rotary		No		G L G-GRAY L- LIMESTONE/DOLOMITE	
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level	
6		NEW BLACK STEEL P E WT 18.97 ASTM A53B ISPCO WELDED JOINT				Surface		172		50 ft. below ground surface	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is	
										18 in. above grade	
										Developed ? Yes	
										Disinfected ? Yes	
										Capped ? Yes	
7. Grout or Other Sealing Material											
Method BRADENHEAD											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?			
NEAT CEMENT GROUT		Surface		170		34 S		No			
Filled & Sealed Well(s) as needed?											
No											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
ME								5905		10-27-2021	
Drill Rig Operator								Lic or Reg #		Date Signed	
RE								7340		10-27-2021	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 08-11-2021

Updated On: 02-15-2022

Review Status: APPROVED