Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAK525

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LONG,MARY	Phone #
Mailing Address: 5051 SACRED FEATHER DRIVE	
City: COLORADO SPRINGS	State: CO Zip Code: 80916

County	Co. Permit #	Notification #	Completed
Door		8499015801	10-11-2021

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
EUCLIDE, MARK E	5905	

Address: EUCLIDE WELL DRILLING INC 2496 STONE RD, STURGEON BAY WI 54235

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well # | Common Well # | Specific Capacity: 0.2

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of NASEWAUPEE

Fire # (if avail.): 2389

Street Address or Road Name and Number: COUNTY S

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.7867 °N	-87.3985 °W			GPS008

SE NE or Govt Lot #	Section	Township	Range
	25	27 N	25 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	38
8	38	170
6	170	262

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Z	T-TAN/BROWN Z-CLAY & GRAVEL	Surface	38
G L	G-GRAY L-LIMESTONE/DOLOMITE	38	262

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P E WT 18.97 ASTM A53B ISPCO WELDED JOINT	Surface	172
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
50 ft. below ground surface

10. Pump Test
Pumping level 200 ft. below surface
Pumping at 30 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	170	34 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME	5905	10-27-2021
Drill Rig Operator	Lic or Reg #	Date Signed
RE	7340	10-27-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 08-11-2021 Updated On: 02-15-2022 Review Status: APPROVED