Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAK526

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DEBAUCHE,MAYA	Phone #
Mailing Address: 2514 COUNTY U	
City: STURGEON BAY	State: WY Zip Code: 54235

County	Co. Permit #	Notification #	Completed
Door		8499298201	08-13-2021

1. Well Location

Town of STURGEON BAY

Fire # (if avail.): 2514

Street Address or Road Name and Number: COUNTY U

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
EUCLIDE, MARK E	5905	

Latitude / Longitude in Decimal Degree (DD): 44.7922 °N -87.3552 °W

Method Code: GPS008

Well Plan Approval #:

SW or Govt Lot #	SW	Section	Township	Range
		21	27 N	26 E

Address: EUCLIDE WELL DRILLING INC 2496 STONE RD STURGEON BAY WI 54235

Approval Date (mm-dd-yyyy):

2. Well Type Replacement

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.2

Reason for replaced or reconstructed well ?: 4" CASING

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	38
8	38	103
6	103	242

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		Z		T-TAN/BROWN Z-CLAY & GRAVEL	Surface	38
G		L		G-GRAY L-LIMESTONE/DOLOMITE	38	242

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL P E WT 18.97 ASTM A53B ISPCO WELDED JOINT	Surface	105
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

60 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	100	32 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
ME	5905	10-27-2021
Drill Rig Operator	Lic or Reg #	Date Signed
RE	7340	10-27-2021

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		40

Comment:

Created On: 08-12-2021 Updated On: 10-15-2026 Review Status: APPROVED