

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAK527		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner GAMBLE,JOHN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 200 OLD KRUEGER ROAD								Town of FORESTVILLE				200							
City FORESTVILLE						State WI		Zip Code 54213				Street Address or Road Name and Number OLD KRUEGER ROAD							
County		Co. Permit #		Notification #		Completed		Subdivision Name				Lot #		Block #					
Door				8500032601		08-20-2021													
Well Constructor (Business Name) EUCLIDE, MARK E				Lic. # 5905		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.6807 °N -87.4582 °W				Method Code GPS008							
Address EUCLIDE WELL DRILLING INC 2496 STONE RD STURGEON BAY WI 54235				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 34 26 N 25 E		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? 4" CASING											
				Approval Date (mm-dd-yyyy)															
Hicap Permanent Well #		Common Well #		Specific Capacity 0															
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 36			Yes Rotary - Mud Circulation No								T Z T-TAN/BROWN Z-CLAY & GRAVEL		Surface 36						
8 36 145			Yes Rotary - Air No								G L G-GRAY L- LIMESTONE/DOLOMITE		36 202						
6 145 202			No Rotary - Air & Foam No																
			No Drill-Through Casing Hammer																
			No Reverse Rotary																
			No Cable-tool Bit ___ in. dia... No																
			No Dual Rotary No																
			No Temp. Outer Casing ___ in. dia																
			No Removed? ___ depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		50 ft. below ground surface				18 in. above grade					
6		NEW BLACK STEEL P E WT 18.97 ASTM A53B ISPCO WELDED JOINT				Surface		142		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
										Pumping at 40 GP M for 1 Hrs.				Capped ? Yes					
										Pumping Method ? Airlift									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? Yes					
Method BRADENHEAD																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? Yes									
NEAT CEMENT GROUT				Surface		140		32 S											
13. Constructor / Supervisory Driller														Lic #		Date Signed			
ME														5905		11-01-2021			
Drill Rig Operator														Lic or Reg #		Date Signed			
RE														7340		11-01-2021			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 08-12-2021

Updated On: 03-24-2022

Review Status: APPROVED