

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAL084		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner TAFT, CODY						Phone # (608)482-1415		1. Well Location				Fire # (if avail.)					
Mailing Address 11500 W RIVERSIDE ROAD								Town of WIOTA				10091					
City GRATIOT						State WI		Zip Code 53541				Street Address or Road Name and Number					
10091 WALNUT ROAD																	
County Lafayette		Co. Permit #		Notification # 8745117105		Completed 09-20-2022		Subdivision Name				Lot #					
												Block #					
Well Constructor (Business Name)				Lic. # 6824		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)							
LOVELACE WELL DRILLING INC										42.6385 °N -90.0165 °W							
						Well Plan Approval #				NE NE		Section Township					
Address 9914 HWY M ARGYLE WI 53504						Approval Date (mm-dd-yyyy)				21 2 N		Range 4 E					
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4				2. Well Type New Well							
										of previous unique well # constructed in							
										Reason for replaced or reconstructed well ?							
3. Well serves 1 # of HOME						Hicap Well ? No											
Private, potable						Hicap Property ? No											
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method														8. Geology			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole						Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)		
8.75 Surface 187											C C-CLAY		Surface 8				
6 187 251			No Rotary - Mud Circulation No								B L B-BROKEN L-LIMESTONE/DOLOMITE		8 10				
			Yes Rotary - Air Yes								L L-LIMESTONE/DOLOMITE		10 25				
			No Rotary - Air & Foam No								H H-SHALE		25 40				
			No Drill-Through Casing Hammer								L L-LIMESTONE/DOLOMITE		40 120				
			No Reverse Rotary								L H L-LIMESTONE/DOLOMITE H-SHALEY		120 175				
			No Cable-tool Bit ___ in. dia... No								L L-LIMESTONE/DOLOMITE		175 251				
			No Dual Rotary No														
			Yes Temp. Outer Casing 10in. dia														
			Yes Removed? 10depth ft. (If NO explain on back side)														
6. Casing, Liner, Screen														9. Static Water Level		11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		128 ft. below ground surface		24 in. above grade					
6		STD BLK, 18.97 #/FT, .280 WALL, WLD JNT, A53B BPEB IPSCO				Surface		187		10. Pump Test		Developed ? Yes					
										Pumping level 180 ft. below surface		Disinfected ? Yes					
										Pumping at 20 GP M for 1 Hrs.		Capped ? Yes					
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No			
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
NEAT CEMENT GROUT				Surface		187		42 S									
13. Constructor / Supervisory Driller						Lic #		Date Signed									
SCK						7011		10-12-2022									
Drill Rig Operator						Lic or Reg #		Date Signed									
HS						9011		10-12-2022									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	140	Septic or Holding, or POWTS Tank	=	120

Comment:

Created On: 10-12-2022

Updated On: 05-23-2023

Review Status: APPROVED