Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAL536

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BURROW, DYLAN	Phone #
Mailing Address: 7886 COUNTY RD 4	
City: HOUSTON	State: MN Zip Code: 55943

County	Co. Permit #	Notification #	Completed
Rusk		8479353901	07-21-2021

Well Constructor (Business Name): MIDWEST HYDROFRACKING LLC	Lic. #: 6799
Address: 31569 150TH AV CORNELL WI 54732-6100	

Facility ID # (Public Wells)

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		2.5

3. Well serves 1 # of CABIN

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

1. Well Location

Town of RUSK

Fire # (if avail.): N 1233

Street Address or Road Name and Number: DEERHEAD POINT RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.3326 °N -91.4227 °W

Method Code: GPS008

NE or Govt Lot #	NE	Section	Township	Range
		24	33 N	9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	4
6	4	105

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	P		T-TAN/BROWN V-NON-CAVING P-HARDPAN	Surface	98
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	98	105

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL, 18.97#/FT A53B WHEATLAND P.E. WELDED	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL TELESCOPIC JOHNSON 18 SLOT SCREEN	102	105

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 31 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MSP	8236	08-08-2021
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MSP		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 08-05-2019 Updated On: 10-15-2026 Review Status: APPROVED