

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAL536		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BURROW, DYLAN						Phone #		1. Well Location				Fire # (if avail.)									
Mailing Address 7886 COUNTY RD 4						Town of RUSK						N 1233									
City HOUSTON						State MN		Zip Code 55943				Street Address or Road Name and Number DEERHEAD POINT RD									
County Rusk		Co. Permit #		Notification # 8479353901		Completed 07-21-2021		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) MIDWEST HYDROFRACKING LLC				Lic. # 6799		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.3326 °N -91.4227 °W				Method Code GPS008							
Address 31569 150TH AV CORNELL WI 54732-6100				Well Plan Approval #		NE NE		Section 24		Township 33 N		Range 9 W									
				Approval Date (mm-dd-yyyy)		or Govt Lot #															
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well				of previous unique well # constructed in											
3. Well serves 1 # of CABIN Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Reason for replaced or reconstructed well ?															
						Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		4		<u>No</u> Rotary - Mud Circulation				<u>No</u>		T V P		T-TAN/BROWN V-NON-CAVING P-HARDPAN		Surface		98			
6		4		105		<u>Yes</u> Rotary - Air				<u>No</u>		T Q Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL		98		105			
						<u>No</u> Rotary - Air & Foam				<u>No</u>											
						<u>No</u> Drill-Through Casing Hammer															
						<u>No</u> Reverse Rotary															
						<u>No</u> Cable-tool Bit ___ in. dia...				<u>No</u>											
						<u>No</u> Dual Rotary				<u>No</u>											
						<u>No</u> Temp. Outer Casing ___ in. dia															
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)															
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		25 ft. below ground surface				24 in. above grade							
6		NEW STEEL, 18.97#/FT A53B WHEATLAND P.E. WELDED				Surface		102		10. Pump Test Pumping level 31 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Test Pump				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
6		STAINLESS STEEL TELESCOPIC JOHNSON 18 SLOT SCREEN				102		105													
7. Grout or Other Sealing Material Method MOUNDED														12. Notified Owner of need to fill & seal ? Yes							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes							
GRANULAR BENTONITE				Surface				2 S													
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														MSP				8236		08-08-2021	
														Drill Rig Operator				Lic or Reg #		Date Signed	
														MSP							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Septic or Holding, or POWTS Tank		70

Comment:

Created On: 08-05-2019

Updated On: 01-07-2022

Review Status: APPROVED