

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAN128		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WARNECKE, KEVIN & SANDRA						Phone # (715)571-6013		1. Well Location				Fire # (if avail.)							
Mailing Address 227641 BOULDER RIDGE CIRCLE						Town of STETTIN													
City WAUSAU						State WI		Zip Code 54401											
County Marathon		Co. Permit #		Notification # 8675641301		Completed 03-02-2022		Subdivision Name AUTUMN HEIGHTS				Lot # 14		Block #					
Well Constructor (Business Name) LANG WELL DRILLING CO INC				Lic. # 4594		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9839 °N -89.7707 °W				Method Code GPS008					
Address 1710 GARFIELD AVE WAUSAU WI 54401-5299				Well Plan Approval #		SE NE		Section 22		Township 29 N		Range 6 E							
						or Govt Lot #													
Approval Date (mm-dd-yyyy)						2. Well Type New Well													
						of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?													
3. Well serves 1 # of HOME						Hicap Well ? No													
Private, potable						Hicap Property ? No													
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)		
10 Surface 10			No Rotary - Mud Circulation				No				D Q C			D- DECOMPOSED/WEATHERED Q-GRANITE C-CLAYEY			Surface 10		
8 10 40			Yes Rotary - Air				Yes												
6 40 300			No Rotary - Air & Foam				No				Q			Q-GRANITE			10 300		
			No Drill-Through Casing Hammer																
			No Reverse Rotary																
			No Cable-tool Bit ___ in. dia...				No												
			No Dual Rotary				No												
			Yes Temp. Outer Casing 8in. dia																
			Yes Removed? 10depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														8. Geology					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		58 ft. below ground surface				11. Well Is					
6		WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE				Surface		40		10. Pump Test				24 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 180 ft. below surface				Developed ? Yes					
										Pumping at 3.6 GP M for 22 Hrs.				Disinfected ? Yes					
										Pumping Method ? Test Pump				Capped ? Yes					
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method BRADENHEAD																			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
NEAT CEMENT GROUT				Surface		40		9 S		NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY									
														13. Constructor / Supervisory Driller					
														Lic #		Date Signed			
														RDL		205		03-08-2022	
														Drill Rig Operator		Lic or Reg #		Date Signed	
														RDL					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment: NO SEPTIC SYSTEM YET

Rehab Type	Rehab Date	Result Text
Hydrofracture	03/02/2022	WELL YIELD BEFORE WAS 2.4 GPM AFTER IS 3.6 GPM

Created On: 03-03-2022

Updated On: 05-17-2022

Review Status: APPROVED