

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAN129		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner FEHLHABER, DEBRA						Phone # (715)305-5549		1. Well Location				Fire # (if avail.)							
Mailing Address C/O KINGDOM HOMES / JEFF REDETZKE 201545 TAMMY LANE								Town of STETTIN											
City MARSHFIELD						State WI		Zip Code 54449											
County Marathon		Co. Permit #		Notification # 8613699402		Completed 03-07-2022		Subdivision Name				Lot #		Block #					
Well Constructor (Business Name) LANG WELL DRILLING CO INC				Lic. # 4594		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.9795 °N -89.7349 °W				Method Code GPS008							
Address 1710 GARFIELD AVE WAUSAU WI 54401-5299				Well Plan Approval #		NW SE		Section 24		Township 29 N		Range 6 E							
				Approval Date (mm-dd-yyyy)		or Govt Lot #													
Hicap Permanent Well #		Common Well #		Specific Capacity 0				2. Well Type New Well				of previous unique well # constructed in							
3. Well serves 1 # of HOME				Hicap Well ? No				Reason for replaced or reconstructed well ?											
Private, potable				Hicap Property ? No															
Heat Exchange ___ # of drillholes				Hicap Potable ? No				Construction Type Drilled											
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method														8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 15			No Rotary - Mud Circulation				No				D Q C		D- DECOMPOSED/WEATHERED Q-GRANITE C-CLAYEY		Surface 15				
8 15 40			Yes Rotary - Air				Yes												
6 40 300			No Rotary - Air & Foam				No				Q		Q-GRANITE		15 300				
			No Drill-Through Casing Hammer																
			No Reverse Rotary																
			No Cable-tool Bit ___ in. dia...				No												
			No Dual Rotary				No												
			Yes Temp. Outer Casing 8in. dia																
			Yes Removed? 15depth ft. (If NO explain on back side)																
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		26 ft. below ground surface				24 in. above grade					
6		WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE				Surface		40		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 180 ft. below surface				Disinfected ? Yes					
										Pumping at 5 GP M for 25 Hrs.				Capped ? Yes					
										Pumping Method ? Test Pump									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ? No					
Method BRADENHEAD																			
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed? No									
NEAT CEMENT GROUT		Surface		40		8 S				NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY									
13. Constructor / Supervisory Driller								Lic #		Date Signed									
RDL								205		03-14-2022									
Drill Rig Operator								Lic or Reg #		Date Signed									
RDL																			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		44	Landfill		1100
POWTS dispersal component (soil absorption unit or mound)		65	Sewer - Building Sanitary		42

Comment: VARIANCE GRANTED BY WISCONSIN DNR ON JUNE 14, 2021, TO DRILL WELL WITHIN 1200 FEET OF LANDFILL.

Variance ID	Variance or Exception Type	Date	Reason
10923	Landfill Variance	06/14/2021	OLD LANDFILL WITHIN 1200 FEET OF NEW WELL

Rehab Type	Rehab Date	Result Text
Hydrofracture	03/07/2022	WELL YIELD BEFORE WAS 53 GPH AFTER IS 5 GPM

Created On: 03-08-2022**Updated On:** 05-20-2022**Review Status:** APPROVED