Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAN129

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FEHLHABER, DEBRA	Phone #: (715)305-549
Mailing Address: C/O KINGDOM HOMES / JEFF REDETZKE 201545 TAMMY LANE	
City: MARSHFIELD	State: WI Zip Code: 54449
County: Marathon	Co. Permit #:
Notification #: 8613699402	Completed: 03-07-2022
Well Constructor (Business Name): LANG WELL DRILLING CO INC	Lic. #: 4594
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 1710 GARFIELD AVE WAUSAU WI 54401-5299	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of STETTIN

Fire # (if avail.):

Street Address or Road Name and Number: 145710 BRISTERS HILL RD. WAUSAU, WI

Subdivision Name: Lot #: Block #:

Latitude / Longitude in Decimal Degree (DD): 44.9795 °N -89.7349 °W

Method Code: GPS008

NW SE or Govt Lot #: Section: 24 Township: 29 N Range: 6 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	15
8	15	40
6	40	300

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 15depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
D	Q	C		D-DECOMPOSED/WEATHERED Q-GRANITE C-CLAYEY	Surface	15
	Q			Q-GRANITE	15	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PLAIN-END STEEL PIPE	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 180 ft. below surface

Pumping at 5 GP M for 25 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	8 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
RDL	205	03-14-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RDL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		44
POWTS dispersal component (soil absorption unit or mound)		65

Type	Qualifier	Distance
Landfill		1100
Sewer - Building Sanitary		42

Comment: VARIANCE GRANTED BY WISCONSIN DNR ON JUNE 14, 2021, TO DRILL WELL WITHIN 1200 FEET OF LANDFILL.

Variance ID	Variance or Exception Type	Date	Reason
10923	Landfill Variance	06/14/2021	OLD LANDFILL WITHIN 1200 FEET OF NEW WELL

Rehab Type	Rehab Date	Result Text
Hydrofracture	03/07/2022	WELL YIELD BEFORE WAS 53 GPH AFTER IS 5 GPM

Created On: 03-08-2022 Updated On: 05-20-2022 Review Status: APPROVED