

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAN130		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner B&K LANG PROPERTIES, LLC						Phone # (715)352-3145		1. Well Location				Fire # (if avail.)									
Mailing Address 130734 COUNTY ROAD N								Town of CASSEL													
City MARATHON						State WI		Zip Code 54448													
County Marathon		Co. Permit #		Notification # 8619287401		Completed 03-09-2022		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) LANG WELL DRILLING CO INC				Lic. # 4594		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.9028 °N -89.9258 °W				Method Code GPS008							
Address 1710 GARFIELD AVE WAUSAU WI 54401-5299				Well Plan Approval #		SW SW		Section 16		Township 28 N		Range 5 E		or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type Replacement											
Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No				Reason for replaced or reconstructed well ? EXISTING WELL HAD BAD CASING											
Private, potable				Hicap Potable ? No		Construction Type Drilled															
3. Well serves 1 # of BUSINESS																					
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.) To (ft.)				
10 Surface 22			No Rotary - Mud Circulation				No				Y			Y-SAND & GRAVEL			Surface 10				
8 22 40			Yes Rotary - Air				Yes				D Q C			D-DECOMPOSED/WEATHERED Q-GRANITE C-CLAYEY			10 22				
6 40 200			No Rotary - Air & Foam				No				Q			Q-GRANITE			22 200				
			No Drill-Through Casing Hammer																		
			No Reverse Rotary																		
			No Cable-tool Bit ___ in. dia...				No														
			No Dual Rotary				No														
			Yes Temp. Outer Casing 9in. dia																		
			Yes Removed? 22depth ft. (If NO explain on back side)																		
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9 ft. below ground surface				24 in. above grade						
6			MARUICHI / LEAVITT, A-53 .280" WALL, PLAIN-END STEEL PIPE				Surface		40		10. Pump Test				Developed ? Yes						
Dia. (in.)			Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 190 ft. below surface				Disinfected ? Yes						
											Pumping at 4.7 GP M for 1 Hrs.				Capped ? Yes						
											Pumping Method ? Test Pump										
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?				Yes			
Method TREMIE PIPE - PUMPED																					
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?						No						
NEAT CEMENT GROUT			Surface		40		20 S		TO BE DONE SOON												
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RDL				205		03-14-2022	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		95

Comment:

Created On: 03-14-2022

Updated On: 05-27-2022

Review Status: APPROVED