Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAN131

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: LANG, ROGER	Phone #: (715)573-4400
Mailing Address: 1708 GARFIELD AVE.	
City: WAUSAU	State: WI — Zip Code: 54401
County: Marathon	Co. Permit #:
Notification #: 8664423702	Completed: 03-14-2022
Well Constructor (Business Name): LANG WELL DRILLING CO INC	Lic. #: 4594
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 1710 GARFIELD AVE WAUSAU WI 54401-5299	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location
Town of STETTIN
Fire # (if avail.):
Street Address or Road Name and Number: STETTIN DR. WAUSAU, WI
Subdivision Name: | Lot #: | Block #:
Latitude / Longitude in Decimal Degree (DD): 44.9731 °N -89.765 °W
Method Code: GPS008
or Govt Lot #: NW NW | Section: 26 | Township: 29 N | Range: 6 E

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	300

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	D	Q	C	R-RED D-DECOMPOSED/WEATHERED Q-GRANITE C-CLAYEY	Surface	40
R	D	Q		R-RED D-DECOMPOSED/WEATHERED Q-GRANITE	40	67
		Q		Q-GRANITE	67	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND WR, ASTM A53 / ASME SA53, 6.625" X .280" SCH 40, PRESSURE TESTED 19.45#/FT., THREADED & COUPLED STEEL	Surface	67
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	20	

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 112 ft. below surface
Pumping at 9.5 GP M for 24 Hrs.
Pumping Method ? Test Pump

11. Well Is
28 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No
NO KNOWN NON-COMPLYING, UNUSED OR UNSAFE WELLS ON THE PROPERTY

13. Constructor / Supervisory Driller	Lic #	Date Signed
RDL	205	03-27-2022
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RDL		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO SEPTIC SYSTEM YET

Rehab Type	Rehab Date	Result Text
Hydrofracture	03/14/2022	WELL YIELD BEFORE WAS 39 GPH AFTER IS 9.5 GPM

Created On: 03-14-2022 Updated On: 07-18-2022 Review Status: APPROVED