

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAN313		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707 Form 3300-077A					
Property Owner BARTSCH, BETTY			Phone # (715)344-8660			1. Well Location Village of PLOVER Street Address or Road Name and Number 2430 WASHINGTON AVE			Fire # (if avail.)		
Mailing Address 2430 WASHINGTON AVE			City PLOVER			State WI		Zip Code 54467			
County		Co. Permit #		Notification #		Completed		Subdivision Name		Lot # Block #	
Portage				9208036301		07-10-2023					
Well Constructor (Business Name) CHETS PLBG & HTG INC				Lic. # 4832		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.4614 °N -89.539 °W		Method Code GPS008	
Address 3001 HOOVER ROAD STEVENS POINT WI 54481-5670				Well Plan Approval #		SE NW Section Township Range or Govt Lot # 22 23 N 8 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Driven Point			
				Approval Date (mm-dd-yyyy)							
Hicap Permanent Well #			Common Well #			Specific Capacity					
3. Well serves 1 # of IRRIGATION Private, non-potable Irrigation Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No			
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)	
2		Surface		30						T S T-TAN/BROWN S-SAND Surface 30	
						No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes	
2		STEEL, SCHEDULE 40 GALVANIZED T&C, THREADED PIPING WITH DRIVE COUPLING.				Surface		26			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
2		48" 10 SLOT STAINLESS STEEL WELL POINT				26		30			
7. Grout or Other Sealing Material Method											
12. Notified Owner of need to fill & seal ? Yes Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller								Lic #		Date Signed	
EL								8042		07-10-2023	
Drill Rig Operator								Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 07-13-2023

Updated On: 08-09-2023

Review Status: APPROVED