

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAN316		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner KENOWSKI, ADELINE				Phone # (715)570-9983		1. Well Location				Fire # (if avail.)	
Mailing Address 2041 ADAMS ST						Village of PLOVER					
City PLOVER				State WI		Zip Code 54467					
County		Co. Permit #		Notification #		Completed		Subdivision Name		Lot #	
Portage				9972739401		08-18-2025				Block #	
Well Constructor (Business Name)				Lic. #		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)		Method Code	
CHETS PLBG & HTG INC				4832				44.46651 °N -89.5435 °W		GPS008	
Address 3001 HOOVER ROAD STEVENSON POINT WI 54481-5670				Well Plan Approval #		NW NW		Section 22		Township 23 N	
				Approval Date (mm-dd-yyyy)		or Govt Lot #				Range 8 E	
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type Replacement					
						of previous unique well # constructed in					
						Reason for replaced or reconstructed well ?					
						NOT PRODUCING					
3. Well serves 1 # of IRRIGATION				Hicap Well ? No		Construction Type Driven Point					
Private, potable Irrigation				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
2		Surface		35		No Rotary - Mud Circulation		No		Geology Codes	
						No Rotary - Air		No		Type, Caving/Noncaving, Color, Hardness, etc...	
						No Rotary - Air & Foam		No		T	
						No Drill-Through Casing Hammer				T-TAN/BROWN	
						No Reverse Rotary				From (ft.)	
						No Cable-tool Bit ___ in. dia...		No		To (ft.)	
						No Dual Rotary		No		Surface	
						No Temp. Outer Casing ___ in. dia				35	
						No Removed? ___ depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
2		STEEL				Surface		31		12 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes	
2		SS 10 SLOT				31		35		Disinfected ? Yes	
7. Grout or Other Sealing Material											
Method											
9. Static Water Level											
19 ft. below ground surface											
10. Pump Test											
Pumping level ___ ft. below surface											
Pumping at ___ GP for ___ Hrs.											
Pumping Method ?											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #											
Date Signed											
JI											
8042											
08-18-2025											
Drill Rig Operator											
Lic or Reg #											
Date Signed											

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 08-18-2025

Updated On: 09-09-2025

Review Status: APPROVED