

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAQ679		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner WE ENERGIES						Phone # (414)221-3010					
Mailing Address 231 WEST MICHIGAN STREET											
City MILWAUKEE				State WI		Zip Code 53203					
County Jefferson		Co. Permit #		Notification #		Completed 06-09-2022					
Well Constructor (Business Name) MUNICIPAL WELL & PUMP/MIDWEST WELL						Lic. # 13		Facility ID # (Public Wells)			
Address 1212 STORBECK DR WAUPUN WI 53963						Well Plan Approval #				Latitude / Longitude in Decimal Degree (DD) 43.163 °N -88.5963 °W	
						Approval Date (mm-dd-yyyy)				Method Code OTH001	
Hicap Permanent Well #		Common Well # 002		Specific Capacity 175		NW NW Section Township Range or Govt Lot # 15 8 N 16 E					
3. Well serves # of UTILITY DOMESTIC						Hicap Well ? No		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled			
Private, potable Industrial				Hicap Property ? Yes							
Heat Exchange ___ # of drillholes				Hicap Potable ? Yes							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			8. Geology		
12 Surface 48			No Rotary - Mud Circulation No						Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.)		
8 48 290			No Rotary - Air Yes						S G S-SAND G-W/GRAVEL/STONES Surface 35		
			No Rotary - Air & Foam No			T C G T-TAN/BROWN C-CLAY G-W/GRAVEL/STONES 35 44					
			No Drill-Through Casing Hammer			T L T-TAN/BROWN L-LIMESTONE/DOLOMITE 44 55					
			No Reverse Rotary			G L G-GRAY L-LIMESTONE/DOLOMITE 55 215					
			No Cable-tool Bit ___ in. dia... No			G L H G-GRAY L-LIMESTONE/DOLOMITE H-SHALEY 215 220					
			Yes Dual Rotary No			I L H I-WHITE L-LIMESTONE/DOLOMITE H-SHALEY 220 260					
			Yes Temp. Outer Casing 12in. dia			G L H G-GRAY L-LIMESTONE/DOLOMITE H-SHALEY 260 280					
			Yes Removed? 48depth ft. (If NO explain on back side)			G L G-GRAY L-LIMESTONE/DOLOMITE 280 290					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
8		CARBON STEEL SCH40, 28.55 PLF A53B SEAH STEEL CORP. WELDED				Surface		48			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method GROUT (FLOAT) SHOE											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
NEAT CEMENT GROUT				Surface		48		60 S			

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 37 ft. below surface

Pumping at 35 GP H for 24 Hrs.

Pumping Method ? Test Pump

11. Well Is

36 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

No

Filled & Sealed Well(s) as needed?

No

13. Constructor / Supervisory Driller

Lic #

Date Signed

TG

4135

08-10-2022

Drill Rig Operator

Lic or Reg #

Date Signed

MR

7819

08-10-2022

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Comment:

Created On: 08-11-2022

Updated On: 05-10-2023

Review Status: APPROVED