Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAQ679

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: WE ENERGIES	Phone #: (414)221-3010
Mailing Address: 231 WEST MICHIGAN STREET	
City: MILWAUKEE	State: WI — Zip Code: 53203
County: Jefferson	Co. Permit #: — Notification #: — Completed: 06-09-2022
Well Constructor (Business Name): MUNICIPAL WELL & PUMP/MIDWEST WELL	Lic. #: 13 — Facility ID # (Public Wells):
Address: 1212 STORBECK DR, WAUPUN WI 53963	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: 002 — Specific Capacity: 0

1. Well Location

Town of IXONIA				Fire # (if avail.):
Street Address or Road Name and Number: N8828 NORTH ROAD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.163 °N -88.5963 °W				Method Code: OTH001
NW NW or Govt Lot #	Section: 15	Township: 8 N	Range: 16 E	

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves # of UTILITY DOMESTIC
Private,potable — Industrial
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? Yes
Hicap Potable ? Yes

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
12	Surface	48
8	48	290

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
Yes	Temp. Outer Casing 12in. dia	
Yes	Removed? 48depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S	G	S-SAND G-W/GRAVEL/STONES	Surface	35
T		C	G	T-TAN/BROWN C-CLAY G-W/GRAVEL/STONES	35	44
T		L		T-TAN/BROWN L-LIMESTONE/DOLOMITE	44	55
G		L		G-GRAY L-LIMESTONE/DOLOMITE	55	215
G		L	H	G-GRAY L-LIMESTONE/DOLOMITE H-SHALEY	215	220
I		L	H	I-WHITE L-LIMESTONE/DOLOMITE H-SHALEY	220	260
G		L	H	G-GRAY L-LIMESTONE/DOLOMITE H-SHALEY	260	280
G		L		G-GRAY L-LIMESTONE/DOLOMITE	280	290

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
8	CARBON STEEL SCH40, 28.55 PLF A53B SEAH STEEL CORP. WELDED	Surface	48
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method GROUT (FLOAT) SHOE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	48	60 S

9. Static Water Level	11. Well Is
25 ft. below ground surface	36 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 37 ft. below surface	Disinfected ? Yes
Pumping at 35 GP H for 24 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TG	4135	08-10-2022
Drill Rig Operator	Lic or Reg #	Date Signed
MR	7819	08-10-2022

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 08-11-2022 Updated On: 10-15-2026 Review Status: APPROVED