

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				AAR693		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner HALVORSEN, DONALD						Phone # (608)558-7162		1. Well Location				Fire # (if avail.)		
Mailing Address N5117 CHURCH ROAD						Town of MOUNT PLEASANT						W4516		
City MONROE						State WI		Zip Code 53566				Street Address or Road Name and Number W4516 WITT ROAD		
County Green		Co. Permit # 22-50		Notification # 8864774704		Completed 08-29-2022		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) LOVELACE WELL DRILLING INC				Lic. # 6824		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.6832 °N -89.5876 °W				Method Code GPS008		
Address 9914 HWY M ARGYLE WI 53504				Well Plan Approval #		SE SE		Section 31		Township 3 N		Range 8 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		2. Well Type New Well								
3. Well serves 1 # of FARM Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
						Hicap Property ? No								
						Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
8.75		Surface		103		<u>Yes</u> Rotary - Mud Circulation <u>No</u>								
6		103		151		<u>No</u> Rotary - Air <u>Yes</u>								
						<u>No</u> Rotary - Air & Foam <u>No</u>								
						<u>No</u> Drill-Through Casing Hammer								
						<u>No</u> Reverse Rotary								
						<u>No</u> Cable-tool Bit ___ in. dia... <u>No</u>								
						<u>No</u> Dual Rotary <u>No</u>								
						<u>No</u> Temp. Outer Casing ___ in. dia								
						<u>No</u> Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)				
X				X-SAND & CLAY				Surface		42				
S				S-SAND				42		51				
N				N-SANDSTONE				51		151				
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		STD BLK, 18.97 #/FT, .280 WALL, WLD JNT, A53B BPEB IPSCO				Surface		103						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
7. Grout or Other Sealing Material														
Method TREMIE PIPE - PUMPED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
NEAT CEMENT GROUT				Surface		103		24 S						
9. Static Water Level														
28 ft. below ground surface														
10. Pump Test														
Pumping level 80 ft. below surface														
Pumping at 25 GP M for 1 Hrs.														
Pumping Method ? Airlift														
11. Well Is														
24 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? No														
Filled & Sealed Well(s) as needed? No														
13. Constructor / Supervisory Driller														
SCK				Lic # 7011		Date Signed 09-29-2022								
Drill Rig Operator				Lic or Reg # 9011		Date Signed 09-29-2022								
HS														

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Animal Barn or Barn Pen	=	100
			Septic or Holding, or POWTS Tank	>	100

Comment:

Created On: 09-29-2022

Updated On: 05-17-2023

Review Status: APPROVED