Well Construction Report
WISCONSIN UNIQUE WELL NUMBER AAT577

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KAREN SCHRAMSKI	Phone #: (612)817-2255
Mailing Address: 1290 208TH ST	
City: ST. CROIX	State: WI Zip Code: 54024

County	Co. Permit #	Notification #	Completed
Polk	w	8822238601	06-21-2022

Well Constructor (Business Name): TRAUT MARK J WELLS INC	Lic #: 5912
Address: 32640 COUNTY RD 133 SAINT JOSEPH MN 56374	

Facility ID # (Public Wells):
Well Plan Approval #:
Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #

Specific Capacity: 0.1

1. Well Location
Town of ST. CROIX FALLS

Fire # (if avail.):

Street Address or Road Name and Number: 1290 208TH ST

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 45.3956 °N -92.5848 °W
Method Code: GPS008

NE	NW	Section	Township	Range
or Govt Lot #		34	34 N	18 W

2. Well Type Replacement
of previous unique well # N/A constructed in

Reason for replaced or reconstructed well ?
RELOCATED WELL

Construction Type: Drilled

3. Well serves 1 # of BUSINESS
Non-community Drillhole
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	86

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	M	C		T-TAN/BROWN M-MEDIUM C-CLAY	Surface	57
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	57	59
T	M	C		T-TAN/BROWN M-MEDIUM C-CLAY	59	68
G	H	C		G-GRAY H-HARD/FIRM C-CLAY	68	82
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	82	86
K	H	K		K-BLACK H-HARD/FIRM K-COBBLES/BOULDERS	86	86

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	PVC, SDR 21, ASTM F480 1.92LBS/FT, WEST LAKE, GLUED BELLED END	Surface	82
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL JOHNSON 4"TEL	82	86

9. Static Water Level
28 ft. below ground surface

10. Pump Test
Pumping level 86 ft. below surface
Pumping at 5 GP M for 4 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
EZ SEAL	Surface	72	7 S

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJT	5911	06-21-2022
Drill Rig Operator	Lic or Reg #	Date Signed
PS		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50
			Sewer - Building Sanitary	>	8

Comment: NOTIFICATON #8822238601. WAS PURCHASED UNDER ST CROIX COUNTY AND NEEDS TO BE CHANGED TO POLK COUNTY.

Created On: 09-08-2022 Updated On: 04-27-2023 Review Status: APPROVED